

STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION

ADDENDUM NO. 1

FOR

TRENCH DRAIN REPAIRS AT
KALAELOA BARBERS POINT HARBOR, OAHU, HAWAII
JOB S10873

April 11, 2023

The following is provided for information:

I. PRE-BID MEETING

A pre-bid meeting for the subject project was held on March 24, 2023, via Microsoft Teams. The Pre-Bid Meeting Minutes is attached.

Please acknowledge receipt of this Addendum No. 1 by recording the date of its receipt in the space provided on page P-4 of the Proposal.



DREANALEE K. KALILI
Deputy Director
Department of Transportation, Harbors

MINUTES TO MEETING

PROJECT: Trench Drain Repairs, Kalaeloa Barbers Point Harbor, Oahu, Hawaii
Job S10873

DATE: March 24, 2023

TIME: 10:00 a.m.

PLACE: Online Teams Meeting

IN ATTENDANCE:

Name	Company/Organization	Email
Emmanuel Legaspi	HDOT Harbors	emmanuel.b.legaspi@hawaii.gov
Grant Okunaga	MKE Associates LLC	grant@mkellc.com
Justin Tanouye	Hawaii Operating Engineers Industry Stabilization Fund	justin@hoeisf.com
Russel Luke	Sea Engineering, Inc.	rluke@seaengineering.com

ITEMS OF DISCUSSION:

1. This meeting is to clarify general questions only. If there is a conflict between what was stated in this meeting and the bid documents, the bid documents shall govern. Any significant changes will be issued through an addendum. A copy of the meeting minutes will be issued to all attendees.
2. Deadline for questions is 2:00 p.m. Hawaii Standard Time (HST) on March 31, 2023. Questions and responses will be published on April 4, 2023.
3. Proposals are due on April 18, 2023, at 2:00 p.m. HST.
4. The scope of work consists of repairing damaged trench drain and furnishing grating.
5. The estimated cost is \$500,000 to \$750,000.
6. Bidders must possess a valid State of Hawaii General Engineering Contractor's "A" license at the time of bidding.
7. Estimated construction start date is October 2023, or earlier.
8. Estimated construction duration is five months.
9. Question: Does the 150 calendar days listed in the Completion Time include the procurement time?

Response: No, the 150 calendar days is for the duration of construction.

10. Question: The project is in a heavily used area with continuing operations. What is the limit of phasing that can be shutdown at a single time?

Response: Drawings show two phases for the trench drain repairs, each approximately 200 feet in length. Bidders shall assume the entire phase (approximately 200 feet) of trench drain may be shutdown at a time.

11. Question: Are barriers around the work area and steel plating over the trench drain required during construction?

Response: Per Section 10.5 of the Specifications, Contractor shall provide, erect, and maintain barricades, including warning signs, lights, etc. around the work area. Bidders may assume no vehicle travel will be allowed over the trench drain during construction.

12. Question: What is the extent of the trench drain cleaning? Is hazardous material anticipated? Will there be any hazardous material testing?

Response: Harbors routinely cleans the trench drain. The purpose of the trench drain cleaning is to clean up any construction debris from the project. No hazardous materials or testing is anticipated. The limit of the trench drain cleaning will be the project area as shown on the drawings.

13. Question: Is painting for grates limited to just the new grates?

Response: Yes, painting is only required for the new grates.

14. Question: Will Harbors salvage the existing trench drain frames?

Response: No, Harbors does not intend to save and salvage the existing trench drain frames.