

ADDENDUM NO. 1

Job No. DOAK07
Kainahola Stream Clearing
Kapaa, Kauai, Hawaii

May 4, 2023

The following are questions from the pre-bid meeting. Additional questions can be found at the HiePro website.

1. Q: How deep is the stream?
A: Unknown
2. Q: Will we be required to install turbidity curtains? What are the limits of the BMPs?
A: This will be determined by the permit that the contractor must get from Department of Health.
3. Q: Do we remove or keep native plant species?
A: Unless it is endangered, remove all vegetation. The botanical study, that the contractor must perform, will identify any rare plants.
4. Q: Is an arborist required on the job?
A: Yes, for the botanical study, but he/she is not expected to monitor the work.
5. Q: Can heavy equipment be parked on the bank, extend over the water and pull back the trees to the bank?
A: No. Our permit from the Army Corps of Engineers requires hand cutting in the stream.
6. Q: Where is the disposal site? What is an “approved disposal site”?
A: There is no pre determined disposal site. It is up to the contractor to find a disposal site and provide documentation or a statement that the waste has been properly handled.
7. Q: Can trees be shred on site?
A: Yes, but the chips/rubbish must be removed. The contractor can use the State owned land adjacent to the stream or negotiate permission with the neighboring owners for staging areas.
8. Q: How do we contact the neighboring lots?
A: Email the project engineer, Bryce Yoshimori, at bryce.e.yoshimori@hawaii.gov and he will send you his phone number.
9. Q: Can we use a mulching head on dry ground areas?
A: Yes, as long as the roots are not pulled up and you are not working in the stream. Chips must be removed from site.

10. Q: What determines the width of cleaning required?

A: The width will be determined by the State's budget. The contractor will know the width when the contract is awarded.

11. Q: How will the State determine how much acreage will be paid for?

A: The contractor must submit daily reports of the work performed where he will document the acreage completed. The State will perform periodic inspections.

The State will only directly pay for the 30' wide strip of work (assuming additive alternates are not awarded). Any clearing done for access or convenience, outside of the contract area, will be considered incidental.