

STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
AIRPORTS

ADDENDUM NO. 2

FOR

CONVERT CARGO BUILDING TO WORKSHOP

DANIEL K. INOUE INTERNATIONAL AIRPORT

HONOLULU, OAHU, HAWAII

STATE PROJECT NO. CO1325-33

JUNE 5, 2023

The following is provided for information.

A. RESPONSES TO REQUESTS FOR INFORMATION (RFIS / QUESTIONS)

The attached Responses to Request for Information (RFI'S/Questions) are provided for information.

Please acknowledge receipt of this Addendum No. 2 by recording the date of its receipt in the space therefore provided on Page P-4 of the Proposal.

Ford Fuchigami

FORD N. FUCHIGAMI
Airports Deputy Director

CONVERT CARGO BUILDING TO WORKSHOP
DANIEL K. INOUE INTERNATIONAL AIRPORT
HONOLULU, OAHU, HAWAII
STATE PROJECT NO. CO1325-33

JUNE 5, 2023

RESPONSES TO REQUESTS FOR INFORMATION (RFIS / QUESTIONS)

1. Bidder Question: We would like to request that the RFI (Questions) Submittal date be extended to June 2nd, 2023, since May 26 is only the day after the initial site visit. - Mahalo

State Response: No.

2. Bidder Question: Sheet F002, Fire Alarm System Notes - Please clarify use of speaker strobes in a potentially loud and noise environment. Typically, in workshops with machinery the use of horns and strobe with a temporal pattern can better achieve the db level required per NFPA 72. Please confirm the use for a voice evac system?

Suggested Solution: FIRE ALARM SYSTEM Notes: 1. A NEW FIRE ALARM SYSTEM COMPATIBLE WITH AIRPORT EXISTING INTELLIGENT ADDRESSABLE CAPABILITIES SHALL BE PROVIDED. DESIGNED AND INSTALLED IN ACCORDANCE WITH NFPA 72, NEC, AND THE SPECIFICATIONS. ALL DEVICES AND EQUIPMENT SHALL BE U.L. LISTED OR FM APPROVED. 2. THE NEW BUILDING FIRE ALARM SYSTEM SHALL BE CAPABLE OF COMMUNICATING WITH THE AIRPORT EXISTING FIRE ALARM SYSTEM. THE SYSTEM SHALL INCLUDE COMMUNICATION HARDWARE TO FACILITATE FUTURE COMMUNICATIONS TO THE EXISTING AIRPORT FIRE ALARM SYSTEM.

State Response: Contractors are to base their bids on what the specifications and plans indicate.