

**KALANIMOKU BUILDING**

Equipment Type	Capacity	Units	Unit#	Manufacturer	Model No	Serial No	Floor	Area Served	Location	Install Date	Remarks	Equip No
Air Handling Unit		cfm	AHU 1-1	Williams	4H30W21360S	319336	1st	Emp. Only next to Rm. 132	Ceiling space			
Air Handling Unit		cfm	AHU 1-10	Lanco			1st	Mauka Ewa Area		2/12/2011		1-10
Air Handling Unit		cfm	AHU 1-11	Lanco			1st	Mauka Exter Area	MensToilet Clg			1-11
Air Handling Unit		cfm	AHU 1-12	Lanco	AH2000	2056-28	1st	Mauka DH Area	WomensTlt Clg			1-12
Air Handling Unit		cfm	AHU 1-2	Lanco	AH2000	2056-19	1st	Women's RR in Rm. 131	Ceiling space			
Air Handling Unit		cfm	AHU 1-3	Lanco	AH2000	2056-19	1st	Women's RR in Rm. 133	Ceiling space			
Air Handling Unit		cfm	AHU 1-4	Lanco			1st	Pub Refer Rm				1-4
Air Handling Unit		cfm	AHU 1-5	Lanco			1st	Land Court Vault				1-5
Air Handling Unit		cfm	AHU 1-6	Lanco			1st	DH Exter Area	MensToilet Clg			1-6
Air Handling Unit		cfm	AHU 1-7	Lanco			1st	Ewa Exter Area	WomensTlt Clg	2/12/2011		1-7
Air Handling Unit		cfm	AHU 1-8	Lanco	AH3000	2056-21	1st	Next to Elev 3&4 by exit	Ceiling space	2/12/2011		
Air Handling Unit		cfm	AHU 1-9	Lanco	AH3001	2056-21	1st	Next to Elev 3&4 by exit	Ceiling space			
Air Handling Unit		cfm	AHU 2-1	Lanco	AH3000	2056	2nd	Makai Ewa Area	Room 230 Clg			2-1
Air Handling Unit		cfm	AHU 2-10	Lanco			2nd	Mauka Ewa Area	Survey Ofc Clg			2-10
Air Handling Unit		cfm	AHU 2-11	Lanco			2nd	Mauka Exter Area	MensToilet Clg			2-11
Air Handling Unit		cfm	AHU 2-12	Lanco			2nd	Mauka DH Area	MensToilet Clg			2-12
Air Handling Unit		cfm	AHU 2-2	Lanco	AH3001	2056	2nd	Makai Ewa Area	WomensTlt Clg - by Rm. 230A			
Air Handling Unit		cfm	AHU 2-3	Lanco	AH3002	2056	2nd	Makai Ewa Area	WomensTlt Clg - by Rm. 230A	2/12/2011		
Air Handling Unit		cfm	AHU 2-4	Lanco	AH4000	2056-28	2nd	Next to Exit by Elev 1 & 2	Ceiling space			
Air Handling Unit		cfm	AHU 2-5	Lanco	AH3000	2056-28	2nd	Next to Exit by Elev 1 & 2	Ceiling space			
Air Handling Unit		cfm	AHU 2-6	Lanco	AH3000	2056-28	2nd	Women's RR next to Rm. 227	Ceiling space	2/12/2011		2-4
Air Handling Unit		cfm	AHU 2-7	Lanco	AH4002	2056-39	2nd	Women's RR next to Rm. 223	Ceiling space			2-5
Air Handling Unit		cfm	AHU 2-8	Lanco	AH3000	2056-26	2nd	Makai Exter Area	WomensTlt Clg	2/12/2011		2-2
Air Handling Unit		cfm	AHU 2-9	Lanco	AH3000	2056-27	2nd	Makai DH Area	WomensTlt Clg			2-3
Air Handling Unit		cfm	AHU 3-1	Lanco	AH3000	2056-25	3rd	Rm. 330	Ceiling space			2-8
Air Handling Unit		cfm	AHU 3-10	Lanco	AH3001	2056-28	3rd	Mauka Ewa Area	Room 310 Clg			
Air Handling Unit		cfm	AHU 3-11	Lanco	AH2000	2053-31	3rd	Mens RR by Rm. 310	Ceiling space			2-6
Air Handling Unit		cfm	AHU 3-12	Lanco	AH3000		3rd	Mens RR by Rm. 310	Ceiling space			2-7
Air Handling Unit		cfm	AHU 3-13	Carrier	39BA0301312	732274927	3rd	Next to Conference Rm. 322B	Corridor Clg			3-13
Air Handling Unit		cfm	AHU 3-2	Lanco	AH3001	2056-27	3rd	Women's RR next to Rm. 330	Ceiling space	2/12/2011		2-9
Air Handling Unit		cfm	AHU 3-3	Lanco	AH3002	2056-26	3rd	Women's RR next to Rm. 330	Ceiling space	2/12/2011		
Air Handling Unit		cfm	AHU 3-4	Lanco	n/a	n/a	3rd	Next to Exit by Elev 1 & 2	Ceiling space			3-1
Air Handling Unit		cfm	AHU 3-5	Lanco	AH4000	2056-28	3rd	Next to Exit by Elev 1 & 2	Ceiling space			
Air Handling Unit		cfm	AHU 3-6	Lanco	AH4001	2056-29	3rd	Mens RR across Rm. 325	Ceiling space			
Air Handling Unit		cfm	AHU 3-7	Lanco	AH3000	2056-30	3rd	Women's RR next to RM. 323	Ceiling space	2/12/2011		
Air Handling Unit		cfm	AHU 3-8	Lanco	AH3001	2056-28	3rd	Next to exit by Elev 3 & 4	Ceiling space	2/12/2011		
Air Handling Unit		cfm	AHU 3-9	Lanco	AH3000	2056-25	3rd	Mauka Ewa Area	Room 310 Clg	2/12/2011		3-10
Air Handling Unit		cfm	AHU 4-1	Lanco			4th	DB Makai area	Design Br Clg	2/12/2011		4-1
Air Handling Unit		cfm	AHU 4-10	Lanco			4th	PMBR Staff Inter	MensToilet Clg	2/12/2011		4-10
Air Handling Unit		cfm	AHU 4-11	Lanco			4th	PMBR Staff Inter	Ewa Corr Clg			4-11
Air Handling Unit		cfm	AHU 4-12	Lanco			4th	Disconnected	Ewa Corr Clg			4-12
Air Handling Unit		cfm	AHU 4-13	Lanco	AH3000	2056-38	4th		WomensTlt Clg	2/12/2011		4-13
Air Handling Unit		cfm	AHU 4-14	Lanco	AH3000	2056-38	4th		WomensTlt Clg			4-14
Air Handling Unit		cfm	AHU 4-15	Lanco	AH3000	2056-38	4th		WomensTlt Clg	2/12/2011		4-15
Air Handling Unit		cfm	AHU 4-16	Lanco			4th	Procurement	Mauka Corr Clg			4-16
Air Handling Unit		cfm	AHU 4-17	Lanco			4th	Syst & Procd	Mauka Corr Clg	2/12/2011		4-17
Air Handling Unit		cfm	AHU 4-18	Lanco			4th	Sys&Pro Mauka	Mauka Corr Clg	2/12/2011		4-18
Air Handling Unit		cfm	AHU 4-19	Lanco			4th	Comptroller Area	Compt Sec Clg			4-19
Air Handling Unit		cfm	AHU 4-2	Lanco			4th	PB Makai area	Design Br Clg	2/12/2011		4-2
Air Handling Unit		cfm	AHU 4-20	Lanco			4th	Dep Compt Area	Compt Sec Clg	2/12/2011		4-20
Air Handling Unit		cfm	AHU 4-21	Lanco			4th	Procurement	MensToilet Clg	2/12/2011		4-21
Air Handling Unit		cfm	AHU 4-22	Lanco			4th	Adm Serv Ofc	MensToilet Clg	2/12/2011		4-22
Air Handling Unit		cfm	AHU 4-23	Trane	MCCX010		4th	Ewa Exter Area	Mech Rm A	6/1/1993		4-23

## KALANIMOKU BUILDING

Equipment Type	Capacity	Units	Unit#	Manufacturer	Model No	Serial No	Floor	Area Served	Location	Install Date	Remarks	Equip No
Air Handling Unit		cfm	AHU 4-24	Trane	MCCX010		4th	DH Exter Area	Mech Rm B	6/1/1993		4-24
Air Handling Unit		cfm	AHU 4-25				4th	Computer Rm	Computer Rm	2/12/2011		4-25
Air Handling Unit		cfm	AHU 4-3	Lanco			4th	PB Makai DH	WomensTlt Clg	2/12/2011		4-3
Air Handling Unit		cfm	AHU 4-4	Lanco			4th	Planning Br Inter	WomensTlt Clg	2/12/2011		4-4
Air Handling Unit		cfm	AHU 4-5	Lanco			4th	DB Makai Ewa	Makai Corr Clg	2/12/2011		4-5
Air Handling Unit		cfm	AHU 4-6	Lanco			4th	Design Br Inter	Makai Corr Clg	2/12/2011		4-6
Air Handling Unit		cfm	AHU 4-7	Lanco			4th	DPW Adm DH	Makai Corr Clg	2/12/2011		4-7
Air Handling Unit		cfm	AHU 4-8	Lanco			4th	Project Mgt Ewa	Makai Corr Clg	2/12/2011		4-8
Air Handling Unit		cfm	AHU 4-9	Lanco			4th	PW Adm&Conf	MensToilet Clg	2/12/2011		4-9
Air Handling Unit		cfm	AHU B-13	Lanco	AH800	2056-13	Bsmt	Storage Room	Loading Dock			
Air Handling Unit		cfm	AHU B-16	Lanco	AH1600	2056-16	Bsmt	Rm B-53	Loading Zone		Unit noisy; motor sheave worn; fan wheel & housing dirty/ corroded; condensate pan corroded/ actuator & spring corroded	
Air Handling Unit	1810	cfm		Magicaire	60-BHW-6		1st	Rm 118	Rm 118 Clg Sp	5/1/1999		1-13
Air Handling Unit	7500	cfm	FCU-1	Carrier	40RR016030	3091F68784	Bsmt	ICSD Keypunch Rm	ICSD Keypunch Rm	11/1/1991		
Air Handling Unit	7500	cfm	FCU-2	Carrier	40RR016030	3091F68786	Bsmt	ICSD Keypunch Rm	ICSD Keypunch Rm	11/1/1991		6
Air-Cooled Condensing Unit	15.75	ton	ACCU-1	Carrier	38AE016600	3091F68953	Bsmt	ICSD Keypunch Rm	Parking Area	11/1/1991	DX Split Pkg Makai Side	
Air-Cooled Condensing Unit	15.75	ton	ACCU-2	Carrier	38AE016600	3091F68954	Bsmt	ICSD Keypunch Rm	Parking Area	11/1/1991	DX Split Pkg Makai Side	
Blower (Ceiling Unit)		cfm		Trane	50166GCLLC4	0763033X	Bsmt		ICSD			
Centrifugal Chiller (R-11)	350	ton	CH-3	Carrier	19XRV	3504Q69885	Bsmt	Tot. Bldg.	Chiller Rm.	1/1/1984	See sheet	
Centrifugal Chiller (R-123)	225	ton	CH - 1	Trane	CVHE 320	L98E03334	Bsmt	Tot. Bldg.	Chiller Rm.	10/1/1998	See sheet	Chiller-2
Centrifugal Chiller (R-123)	225	ton	CH - 2	Trane	CVHE 320	L98E03320	Bsmt	Tot. Bldg.	Chiller Rm.	10/1/1998	See sheet	Chiller-1
Chilled Water Pump		gpm	CHWP-1	Paco	29-40155		Bsmt	Tot. Bldg.	Chiller Rm.			
Chilled Water Pump		gpm	CHWP-2	Paco	29-40155		Bsmt	Tot. Bldg.	Chiller Rm.			
Chilled Water Pump		gpm	CHWP-3	Paco	29-40155		Bsmt	Tot. Bldg.	Chiller Rm.			
Chiller Purge Unit			CP-1	Trane	PRG-10M-3		Bsmt	Tot. Bldg.	Chiller Rm.	12/1/1993		
Chiller Purge Unit			CP-2	Trane			Bsmt	Tot. Bldg.	Chiller Rm.	10/1/1998	Effective:12/1/99	
Chiller Purge Unit			CP-3	Trane			Bsmt	Tot. Bldg.	Chiller Rm.	10/1/1998	Effective:12/1/99	
Condenser Water Pump		gpm	CWP-1	Paco	GMP 860	KYG69347A	Bsmt	Tot. Bldg.	Chiller Rm.			
Condenser Water Pump		gpm	CWP-2	Paco	GMP 860	KYG69347B	Bsmt	Tot. Bldg.	Chiller Rm.			
Condenser Water Pump		gpm	CWP-3	Paco	GMP 860	KYG69347C	Bsmt	Tot. Bldg.	Chiller Rm.		+F564	
Cooling Tower		ton	CT-1	BAC	VTO-155-N	U040571601	Roof	Tot. Bldg.	Roof		See sheet	
Cooling Tower		ton	CT-2	BAC	VXT-150WC	82-5094M	Roof	Tot. Bldg.	Roof		See sheet	
Cooling Tower		ton	CT-3	BAC	VXT-150LC	85-9264M	Roof	Tot. Bldg.	Roof		See sheet	
Cooling Tower		ton	CT-4	BAC	VXT-150LC	85-9263M	Roof	Tot. Bldg.	Roof		See sheet	
Cooling Tower		ton	CT-5	BAC	VXT-150WC	82-5095M	Roof	Tot. Bldg.	Roof		See sheet	
Exhaust Fan		cfm	EF-10	Barry		41059	Roof		Roof			EF-10
Exhaust Fan		cfm	EF-11				Bsmt		Chiller Room			EF-11
Exhaust Fan		cfm	EF-12				Bsmt		Chiller Room			EF-12
Exhaust Fan		cfm	EF-13	Bohn	HCS 217LF	BUH 7125	Bsmt		Loading Dock		Exhaust duct & bracket exiting bldg corroded; intake grilles plugged & corroded	EF-13
Exhaust Fan		cfm	EF-14	Penn			5th	MensToilet Rm	MensToilet Clg			EF-14
Exhaust Fan		cfm	EF-15	Penn			5th	WomensTlt Rm	WomensTlt Clg			EF-15
Exhaust Fan		cfm	EF-19	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room A			EF-19
Exhaust Fan		cfm	EF-20	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room A			EF-20
Exhaust Fan		cfm	EF-21	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room B			EF-21
Exhaust Fan		cfm	EF-22	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room B			EF-22
Exhaust Fan		cfm	EF-23	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room C			EF-23
Exhaust Fan		cfm	EF-24	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room C			EF-24
Exhaust Fan		cfm	EF-25	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room D			EF-25
Exhaust Fan		cfm	EF-26	Indust. Accoustics			Bsmt	Bsmt Prkg Gar	Fan Room D			EF-26
Exhaust Fan		cfm	EF-3	Joy Mfg. Co.	6026 1/2 870		Roof	Bsmt Prkg Gar	Roof	1/1/1975	mauka side	EF-3
Exhaust Fan		cfm	EF-4	Joy Mfg. Co.			Roof	Bsmt Prkg Gar	Roof	1/1/1975	mauka side	EF-4

## KALANIMOKU BUILDING

Equipment Type	Capacity	Units	Unit#	Manufacturer	Model No	Serial No	Floor	Area Served	Location	Install Date	Remarks	Equip No
Exhaust Fan		cfm	EF-5	Joy Mfg. Co.			Roof	Bsmt Prkg Gar	Roof	1/1/1975	mauka side	EF-5
Exhaust Fan		cfm	EF-6	Joy Mfg. Co.			Roof	Bsmt Prkg Gar	Roof	1/1/1975	makai side	EF-6
Exhaust Fan		cfm	EF-7	Joy Mfg. Co.			Roof	Bsmt Prkg Gar	Roof	1/1/1975	makai side	EF-7
Exhaust Fan		cfm	EF-8	Joy Mfg. Co.			Roof	Bsmt Prkg Gar	Roof	1/1/1975	makai side	EF-8
Exhaust Fan		cfm	EF-9	Barry	365-AF-CW	4 VK 0385	Roof		Roof			EF-9
Exhaust Fan - Cabinet/Inline	120	cfm	EF-16	Greenheck	CSP-218	98A12332	5th	Payroll Project	Payroll Project	5/1/1998		
Fan Coil Unit		cfm	AHU 1	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 10	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 11	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 12	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 2	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 3	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 4	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 5	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit	1200	cfm	AHU 5-1	Int'l Environm'l	14HP4-5	87-17995	5th	Quality Control	Corridor Clg	1/1/1988		5-1
Fan Coil Unit	1270	cfm	AHU 5-2	Int'l Environm'l	14HP4-5	87-17995	5th	Quality Control	Corridor Clg	1/1/1988		5-2
Fan Coil Unit	1270	cfm	AHU 5-3	Int'l Environm'l	14HP4-5	87-17995	5th	Q.C. Conf. Rm.	Corridor Clg	1/1/1988		5-3
Fan Coil Unit	710	cfm	AHU 5-4	Int'l Environm'l	14HP4-5	87-17995	5th	Q.C. Library	Corridor Clg	1/1/1988		5-4
Fan Coil Unit	400	cfm	AHU 5-5	Int'l Environm'l	42588	87-17995	5th		Corridor Clg	1/1/1988		5-5
Fan Coil Unit		cfm	AHU 5-6	Carrier			5th	TeleComm Rm	TeleComm Rm	1/1/1988		5-6
Fan Coil Unit	800	cfm	AHU 5-7	Carrier	42BHB08LC3R	09387615313	5th	Payroll Project	Corridor Clg	5/1/1998		5-7
Fan Coil Unit		cfm	AHU 6	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 7	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 8	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit		cfm	AHU 9	Lanco			Bsmt	ICSD Mech Rm	ICSD Mech Rm			B-7 & standby
Fan Coil Unit	2645	cfm	B-01	McQuay	SCB301BR		Bsmt	Telecon Netwk	Tele Netwk Clg	1/1/1992		B-01
Fan Coil Unit		cfm	B-07	Lanco			Bsmt	EMCS Room	EMCS Rm Clg			B-07
Fan Coil Unit		cfm	B-1	Lanco			Bsmt	ICSD Key punch Rm	ICSD Lunch Rm			B-1
Fan Coil Unit	1585	cfm	B-10	McQuay	SCB161BR		Bsmt	ICSD B20 Offices	WomensTlt Clg	1/1/1992	DH mauka	B-10
Fan Coil Unit	1360	cfm	B-10A	McQuay	SCB161BL		Bsmt	ICSD B20 Offices	Prtn. Aisle Clg	1/1/1992	Ewa mauka	B-10A
Fan Coil Unit	2000	cfm	B-11	McQuay	SCB201BR		Bsmt	ICSD Tech Lib	WomensTlt Clg	1/1/1992		B-11
Fan Coil Unit	3070	cfm	B-12	McQuay	SCB301BL		Bsmt	ICSD B20 Offices	Green Corr Clg	1/1/1992	mauka side	B-12
Fan Coil Unit		cfm	B-13	Lanco			Bsmt	Electr/Cust Rms	Electrician Rm			B-13
Fan Coil Unit	2125	cfm	B-14	McQuay	SCB301BR		Bsmt	Telecon Offices	MensToilet Clg	1/1/1992		B-14
Fan Coil Unit	1665	cfm	B-14A	McQuay	SCB161BR		Bsmt	Telecon Offices	Corridor Clg	1/1/1992		B-14A
Fan Coil Unit		cfm	B-15	Lanco			Bsmt	Telecon ConfRm	Coffee Rm Clg			B-15
Fan Coil Unit		cfm	B-16	Lanco			Bsmt	Bldg Mgrs Ofcs	Custod Stor Rm			B-16
Fan Coil Unit		cfm	B-17	Lanco			Bsmt	Mail/Grds Rms	Mail Room			B-17
Fan Coil Unit	1208	cfm	B-18	McQuay	SCD161BR		Bsmt	Telecon AV Rm	Side Corr Clg	1/1/1992		B-18
Fan Coil Unit		cfm	B-19	Trane	CLCH6C-501	N87G30334	Bsmt	ICSD Repro Rm	ICSD Repro Clg			B-19
Fan Coil Unit		cfm	B-2	Lanco			Bsmt	ICSD Offices	MensToilet Clg			B-2
Fan Coil Unit		cfm	B-20	Carrier	42DC1		Bsmt	ICSD Conf Rm	ICSD Conf Clg			B-20
Fan Coil Unit		cfm	B-21	Carrier	42BH3		Bsmt	ICSD Key punch Rm	ICSD Keypu Clg			B-21
Fan Coil Unit		cfm	B-22	Carrier	42BH3		Bsmt	ICSD Key punch Rm	ICSD Keypu Clg			B-22
Fan Coil Unit		cfm	B-23	Carrier	42BH3		Bsmt	ICSD Programrs	ICSD Programrs			B-23
Fan Coil Unit		cfm	B-24	Carrier	42BH2		Bsmt	ICSD Progr Ofc	ICSD Progr Ofc			B-24
Fan Coil Unit		cfm	B-3	Lanco			Bsmt	ICSD Recept	WomensTlt Clg			B-3
Fan Coil Unit		cfm	B-4	Lanco			Bsmt	ICSD Programrs	Blue Corr Clg			B-4
Fan Coil Unit	2535	cfm	B-5	McQuay	SCB301BR		Bsmt	ICSD B20 Offices	Blue Corr Clg	1/1/1992	makai side	B-5
Fan Coil Unit	1300	cfm	B-8	McQuay	SCB161BL		Bsmt	ICSD B20 Offices	MensToilet Clg	1/1/1992	DH makai	B-8
Fan Coil Unit	1795	cfm	B-8A	McQuay	SCB161BR		Bsmt	ICSD B20 Offices	Prtn. Aisle Clg	1/1/1992	Ewa makai	B-8A
Fan Coil Unit	1450	cfm	B-9	McQuay	SCB161BR		Bsmt	ICSD B20 Offices	MensToilet Clg	1/1/1992	DH center	B-9
Fan Coil Unit	1505	cfm	B-9A	McQuay	SCB161BR		Bsmt	ICSD B20 Offices	Prtn. Aisle Clg	1/1/1992	Ewa center	B-9A

**KALANIMOKU BUILDING**

Equipment Type	Capacity	Units	Unit#	Manufacturer	Model No	Serial No	Floor	Area Served	Location	Install Date	Remarks	Equip No
Fan Coil Unit		cfm		Lanco			Bsmt	Mag Tape Stor	Mag Tape Stor			B-6 & standby
Fan Coil Unit		cfm		Lanco			Bsmt	Mag Tape Stor	Mag Tape Stor			B-6 & standby
Fan Coil Unit		cfm		McQuay	SCD061A	2367/?	Bsmt	Mag Tape Vault	Mag Tape Vault			B-6A & standby
Fan Coil Unit		cfm		McQuay	SCD061A	2367/?	Bsmt	Mag Tape Vault	Mag Tape Vault			B-6A & standby
Fan Coil Unit - Vertical Mount		cfm		AirFlow	CCT-05C	024FD017018	Bsmt	ICSD Comp Rm	ICSD Comp Rm	9/1/1994	+F623	
Fan Coil Unit - Vertical Mount		cfm		AirFlow	CCT-05C	024FD017018	Bsmt	ICSD Comp Rm	ICSD Comp Rm	9/1/1994		
Pre-Cooler AHU	40567	cfm	S-1	Carrier	39T-74		Roof	Tot. Bldg.	Roof	9/1/2003		S-1
Refrigerant/Oxygen Monitor System				Trane	RMWD1100AA0		Bsmt	Chiller Rm.	Chiller Rm.	10/1/1998	Effective:12/1/99	
Variable Drive			VFD 4-23	ABB			4th	AHU 4-23				
Variable Drive			VFD 4-24	ABB			4th	AHU 4-24				
Variable Drive			VFD-CHW1	ABB			Bsmt					
Variable Drive			VFD-CHW2	ABB			Bsmt					
Variable Drive			VFD-CHW3	ABB			Bsmt					
Variable Drive			VFD-T1	ABB			Roof		Roof		Cooling Tower #1	
Variable Drive			VFD-T2	ABB			Roof		Roof		Cooling Tower #2	
Variable Drive			VFD-T3	ABB			Roof		Roof		Cooling Tower #3	
Variable Drive			VFD-T4	ABB			Roof		Roof		Cooling Tower #4	
Variable Drive			VFD-T5	ABB			Roof		Roof		Cooling Tower #5	