

Kinau Hale, 1250 Punchbowl Street – Safety Repairs

Addendum No. 1

Scope of Work - Clarification

Item 2c. Replace/add exterior floor tiles on Makai entry:

The tiles shall be:

- 6x6 floor tiles
- Glazed porcelain
- Non-slip approved for exterior application.
- Commercial Grade
- Color to be determined with submittal

Item 3a, 4a and 5c. Encapsulate existing plaster ceiling:

The encapsulation shall be suspended stretch fabric material made of polyurethane covered polyester.