

State of Hawaii
DEPARTMENT OF LAND AND NATURAL RESOURCES
ENGINEERING DIVISION
1151 Punchbowl Street, Room 221
Honolulu, Hawaii 96813

ADDENDUM NO. 1

TO

Job No. C00TK91A
Division of Aquatic Resources
Kauai Work Station Site Work
Kapaa, Kauai, Hawaii

May 2, 2024

This addendum as issued shall become part of the Contract Documents for the above subject project.

GENERAL INFORMATION

1. Question: It is unclear where the existing concrete pad ends on the southern side. Do the new posts for the chain link fence need to be drilled into the pad, or be installed along the edge of the pad?

Response: The new posts for the chain link fence on the southern side will be drilled into the existing concrete pad right along the property line.

Engineering Division



Carty S. Chang
Chief Engineer