

**STATE OF HAWAII  
DEPARTMENT OF TRANSPORTATION  
HARBORS**

**ADDENDUM NO. 1  
FOR  
REMOVE RAIL FOOTING ON CONCRETE APRON,  
KAUMALAPAU HARBOR, LANAI  
JOB S30229**

**May 30, 2024**

This Addendum shall make the following amendments to Bid Documents:

**A. NOTICE TO BIDDERS**

- I. Prospective bidders are **hereby notified** that receiving of sealed bids, scheduled for **May 31, 2024, at 2:00 p.m., Hawaii Standard Time (HST)**, is **HEREBY POSTPONED** until **JUNE 7, 2024, at 2:00 p.m., HST**.

The attached **NOTICE TO BIDDERS** dated **5/30/2024** shall be incorporated and made a part of the **NOTICE TO BIDDERS**.

The following is provided for your information:

**B. RESPONSE TO REQUEST FOR INFORMATION (RFI / QUESTIONS)**

The attached Response to Request for Information is provided for your information.

Please acknowledge receipt of this Addendum No. 1 by recording the date of its receipt in the space provided on page P-4 of the PROPOSAL.

  
\_\_\_\_\_  
DREANALEE K. KALILI  
Deputy Director of Transportation for Harbors

**NOTICE TO BIDDERS**  
Hawaii Revised Statutes (HRS),  
Chapter 103D

The receiving of bids for **REMOVE RAIL FOOTING ON CONCRETE APRON, KAUMALAPAU HARBOR, LANAI, HAWAII - JOB S30229**, will begin as of the HiePRO Release Date. Bidders shall register and submit complete bids through HiePRO only. Refer to the following HiePRO link for important information on Vendor Registration:  
<https://hiepro.ehawaii.gov/welcome.html>.

The solicitation plans, specifications, proposal, and additional documents designated or incorporated by reference shall be available in HiePRO.

HiePRO OFFER DUE DATE & TIME scheduled for May 31, 2024, at 2:00 p.m., Hawaii Standard Time (HST), is **HEREBY POSTPONED** until **JUNE 7, 2024**, at 2:00 p.m., HST.

**Bidders shall submit and upload the complete proposal to HiePRO prior to the offer due date and time. Proposals received after said due date and time shall not be considered.**

**Any additional support documents explicitly designated as confidential and/or proprietary shall be uploaded as a separate file to HiePRO. Bidders shall not include confidential and/or proprietary documents as part of their proposal. The record of each bidder and their respective proposal shall be open to public inspection. **FAILURE TO UPLOAD THE PROPOSAL TO HiePRO SHALL BE GROUNDS FOR REJECTION.****

  
DREANALEE K. KALILI

Deputy Director of Transportation for Harbors

**RESPONSE TO REQUEST FOR INFORMATION (RFI / QUESTIONS)**

Questions for solicitation: B24002474 Job S30229 –  
Remove Rail Footing on Concrete Apron, Kaumalapau  
5/30/2024

**1. Can 5,000 psi concrete be supplemented for Sika Concrete Patch?**

A: No, the concrete shall have similar properties to the specified Sikacrete 211 SCC Plus and shall be polymer modified containing silica fume and a corrosion inhibitor and reach a minimum seven-day strength of 5,000 psi.

**2. Please provide rebar details for patch areas.**

A: Repairs will be unreinforced with a polymer modified repair material.

**3. Can hot mix be used instead of cold patch? If so what specifications?**

A: Yes, HMA State Mix IV or V is an approved equal material and may be used in lieu of cold patch material.