

**STATE OF HAWAII  
DEPARTMENT OF TRANSPORTATION  
HARBORS**

**ADDENDUM NO. 1  
FOR  
REPAIR LIGHT POLES AT PIERS 1 AND 2,  
KAHULUI HARBOR, MAUI, HAWAII  
JOB S30217**

**December 9, 2024**

This Addendum shall make the following amendment(s) to the Solicitation:

**A. NOTICE TO BIDDERS**

1. Delete **NOTICE TO BIDDERS**, HiePRO release date 11/15/2024, in its entirety and replace it with attached **NOTICE TO BIDDERS**, dated 12/9/2024.

The following is provided for information.

**B. PRE-BID MEETING MINUTES**

1. The attached **PRE-BID MEETING MINUTES** are provided for information.

Please acknowledge receipt of this **ADDENDUM NO. 1** by recording the date of its receipt in the space provided on the **PAGE P-4** of the Proposal.

  
\_\_\_\_\_  
DREANALEE K. KALILI

Deputy Director of Transportation for Harbors

**NOTICE TO BIDDERS**  
Hawaii Revised Statutes (HRS),  
Chapter 103D

The receiving of bids for **REPAIR LIGHT POLES AT PIERS 1 AND 2, KAHULUI HARBOR, MAUI, HAWAII, JOB S30217**, will begin as of the HiePRO Release Date.

Bidders shall register and submit complete bids through HiePRO only. Refer to the following HiePRO link for important information on Vendor Registration:

<https://hiepro.ehawaii.gov/welcome.html>.

The solicitation plans, specifications, proposal, and additional documents designated or incorporated by reference shall be available in HiePRO.

HiePRO OFFER DUE DATE & TIME is December 19, 2024, at 2:00 p.m., Hawaii Standard Time (HST). **Bidders shall submit and upload the complete proposal to HiePRO prior to the offer due date and time. Proposals received after said due date and time shall not be considered. Any additional support documents explicitly designated as confidential and/or proprietary shall be uploaded as a separate file to HiePRO. Bidders shall not include confidential and/or proprietary documents as part of their proposal. The record of each bidder and their respective proposal shall be open to public inspection. FAILURE TO UPLOAD THE PROPOSAL TO HiePRO SHALL BE GROUNDS FOR REJECTION.**

The scope of work consists of repairing light poles at Piers 1 and 2 at Kahului Harbor, Maui, Hawaii. The estimated cost of construction is between \$2,000,000 and \$3,000,000.

To be eligible for award, bidders shall possess a valid State of Hawaii General Engineering Contractor's "A" or Specialty Contractor's "C-13" license **at the time of bidding.**

The Hawaii Department of Transportation, Air and Water Transportation Facilities Division, 2016 GENERAL PROVISIONS FOR CONSTRUCTION PROJECTS, applicable to this project are available on the internet at: <http://hidot.hawaii.gov/administration/con/>.

A virtual pre-bid conference is scheduled for November 22, 2024 at 9:00 a.m., HST. Interested bidders shall contact Mr. Branden Sumida, Project Manager, directly at branden.sumida@hawaii.gov, no later than five working days prior to the scheduled pre-bid conference to receive the meeting invitation. All prospective bidders and/or their respective representatives are encouraged to attend, however, attendance is not mandatory. All information presented at the pre-bid conference shall be provided for clarification and information only. Any amendments to the solicitation shall be made by formal addendum and posted in HlePRO.

All Request for Information (RFI) questions and Substitution Requests shall be submitted in HlePRO **no later than December 2, 2024 at 2:00 p.m., HST**. RFI questions received after the stated deadline shall not be addressed. Substitution Requests received after the stated deadline shall not be considered. Verbal RFI(s) shall not receive a response. All responses to RFI questions shall be provided for clarification and information only and issued by formal addendum. Any amendments to the solicitation shall be made by formal addendum and posted in HlePRO.

If there is a conflict between the solicitation and information stated in the pre-bid conference, the meeting minutes, and/or the responses to RFI questions, the solicitation shall govern and control, unless as amended by formal addendum.

**Apprenticeship Preference.** A five percent bid adjustment for bidders that are party to apprenticeship agreements pursuant to HRS § 103-55.6 is applicable to this project.

Employment of State Residents on Construction Procurement Contracts. Compliance with HRS § 103B-3 is a requirement for this project whereby a minimum of 80 percent of the bidder's work force on this project shall consist of Hawaii residents.

Campaign Contributions by State and County Contractors. Contractors are hereby notified of the applicability of HRS § 11-355 which states that campaign contributions are prohibited from specified State or County government contractors during the term of the contract if the contractors are paid with funds appropriated by a legislative body. For more information, contact the Campaign Spending Commission at (808) 586-0285.

Protests. Any protest of this solicitation shall be submitted in writing to the Director of Transportation, in accordance with HRS § 103D-701 and Hawaii Administrative Rules § 3-126.

The Equal Employment Opportunity Regulations of the Secretary of Labor implementing Executive Order 11246, as amended, shall be complied with on this project.

The U.S. Department of Transportation Regulation entitled "Nondiscrimination in Federally Assisted Programs of the U.S. Department of Transportation", Title 49, Code of Federal Regulations (CFR), Part 21, is applicable to this project. Bidders are hereby notified that the Department of Transportation shall affirmatively ensure that the contract entered into pursuant to this advertisement shall be awarded to the lowest responsible bidder without discrimination on the grounds of race, color, national origin, or sex (as directed by 23 CFR, Part 200).

For additional information, contact Branden Sumida, Project Manager, by phone at (808) 587-1873, or by email at [branden.sumida@hawaii.gov](mailto:branden.sumida@hawaii.gov).

The State reserves the right to reject any or all proposals and to waive any defects in said proposals in the best interest of the public.

  
DREANALEE K. KALILI  
Deputy Director of Transportation for Harbors

HIePRO RELEASE DATE: December 9, 2024

**STATE OF HAWAII  
DEPARTMENT OF TRANSPORTATION  
HARBORS**

**PRE-BID MEETING MINUTES**

**DATE:** November 22, 2024 **TIME:** 9:00 a.m.

**LOCATION:** Honolulu Harbor, Oahu, Hawaii  
Tele-Conference

**PROJECT:** Repair Light Poles at Piers 1 and 2  
Kahului Harbor, Maui, Hawaii  
Job S30217

**I. INTRODUCTION**

Attendees introduce themselves (name and company).

**II. IMPORTANT ITEMS**

1. This meeting is to clarify general questions only. If there is a conflict between what was stated in this meeting and the bid documents, the bid documents shall govern. Any significant changes will be issued through an addendum. A copy of the meeting minutes will be issued to all attendees.
2. Deadline for questions and RFIs is on December 2, 2024 at 2:00 p.m., HST. All questions must be submitted through HiePRO.
3. Proposals Due on December 19, 2024, at 2:00 p.m., HST.
4. The scope of work consists of repairing light poles at Piers 1 and 2 at Kahului Harbor, Maui, Hawaii.
5. The estimated cost is between \$2,000,000 to \$3,000,000.
6. Key Information
  - a. Bidders must possess a valid State of Hawaii General Engineering Contractor's "A" license at the time of bidding.

### **III. GENERAL DISCUSSIONS**

1. Question: What are the security requirements for the project?

Response: See Article 10, section 10.11, of the specifications.

2. Question: Who is responsible for installing the nodes connecting to the existing wireless GE light control system?

Response: The nodes will be installed by the Contractor, who will have to coordinate with Harbors to connect to the existing system.

3. Question: Is there a preferred manufacturer for poles and light fixtures? Is light testing required?

Response: See sheets E-11 to E-13 of the contract drawings for light fixture requirements. The pole provided shall meet the requirements shown on the contract drawings (see sheets E-11 to E-13). See Article 14, section 14.5, of the specifications for testing requirements.

4. Question: Will security cameras need to be reinstalled and can the conduits be placed inside the pole?

Response: Cameras shall be reinstalled by the Contractor, as per sheets E-10 and E-13 of the contract drawings. For the purpose of bidding, assume reinstalled items will match existing.

5. Question: Will current pole foundations be replaced?

Response: At Pier 1, existing foundations will be reused and pedestals replaced to accommodate pole anchors. At Pier 2, new foundations and pedestals will be installed.

**MEETING ATTENDANCE SHEET**  
**Pre-Bid Meeting**

Project Name: Repair Light Poles at Piers 1 and 2  
Kahului Harbor, Maui, Hawaii  
Project No. S30217  
Meeting Location: Honolulu Harbor, Oahu, Hawaii, Tele-Conference  
Date: November 22, 2024 9:00 a.m.

Name: Branden Sumida	Company: DOT Harbors	Email: branden.sumida@hawaii.gov
Name: Julian Cheng	Company: Coffman Engineers	Email: julian.cheng@coffman.com
Name: Jillian Sumitomo	Company: MKE Associates LLC	Email: jillian@mkellc.com
Name: Alex Nakasato	Company: MKE Associates LLC	Email: alex@mkellc.com
Name: Christopher Sutherland	Company: Up-Country Electric Company, Inc.	Email: chris@upcountryelectric.com