ADDENDUM #1

Wahiawa Library Temporary Office Repair

Located at 823 California Avenue, A-11

A. Since there is no demolition, there is no hazmat report available. The proposed new vinyl flooring and cove base work are deleted from this contract. The existing carpet squares and cove base will remain.

B. Contract is 30 days, start date of 04/07/2025 and ends 05/06/2025.

C. Additional questions that were emailed:

13. Q: There are five each floor receptacle in office space, are these receptacles to remain or be removed?

    A: The floor receptacles will be removed/blanked by others (not in this contract) and flush to existing carpet tile floor.

14. Q: Throughout the office space and back storage rooms, light fixtures are not operable. Under this contract, do we have to replace or fix these light fixtures? Please clarify.

    A: The existing light fixtures located in the drop ceiling are to be removed/disposed and 15 new 2 X 4 LED light fixtures are to be installed with all new ceiling tiles. Light fixtures in the office space, back storage, and bathroom are to remain.

D. Attendance Log for the site visit.