



2024



Pahoa Public Library


15-3070 Pahoa Kalapana Rd
Pahoa, HI 96778
808-965-2171

Building Contact: Kathryn Tipton
Title: Site Contact

Company: Guardian Fire, LLC
Contact: Jared David-Chapman
Title: Inspector

Inspection Date: Dec 17, 2024

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Pahoa Public Library 15-3070 Pahoa Kalapana Rd Pahoa, HI 96778 United States of America	Contact: Kathryn Tipton
	Phone: 808-965-2171
	Fax:
	Mobile:
	Email: facilities@librarieshawaii.org

Inspection Performed By

Guardian Fire, LLC 73-5577 KAUHOLA ST KAILUA KONA, HI 96740-2642 United States of America	Inspector: Jared David-Chapman
	Phone: 808-896-4515
	Fax:
	Mobile:
	Email: jared@gfhawaii.com

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	4	100.00%	4	100.00%	3	75.00%	1	25.00%
Totals	4	100%	4	100.00%	3	75.00%	1	25.00%

Certification

Company: Guardian Fire, LLC


Inspector: Jared David-Chapman



Signed: Dec 17, 2024

Building: Pahoa Public Library

Contact: Kathryn Tipton



Signed: Dec 17, 2024

DISCREPANCY REPORT

Generated by: BuildingReports.com

The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Building: Pahoia Public Library

Items listed for Recall or Replacement/Upgrade

Device Type	Manufacturer	Model Number	Date	Qty
-------------	--------------	--------------	------	-----

No items found during this inspection.

Discrepancies

ScanID	Location	Problem	Reference
--------	----------	---------	-----------

FIRE

Fire Extinguisher, A.B.C., 16#

H000001	Book Drop	Date Expired	NFPA 10 4.4.2
---------	-----------	--------------	---------------



Code References

NFPA 10 4.4.2	Any fire extinguisher that can no longer be serviced in accordance with the manufacturer's maintenance manual is considered obsolete and shall be removed from service.
----------------------	---

PROPOSED SOLUTIONS REPORT

Generated by: BuildingReports.com

The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.

Building: Paho Public Library

ScanID	Location	Solution	Model #	Cost	Fix
FIRE					
Fire Extinguisher, A.B.C., 16#					
H000001	Book Drop	Add New	1000 series	T/M	<input type="checkbox"/>

Total: T/M **PO #:** (none)

NOTES & RECOMMENDATIONS

Generated by: BuildingReports.com

The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.

Building: Pahoia Public Library

Note	Device Type	Location	Comment	ScanID
FIRE				
1	Fire Extinguisher	Book Drop	Date Expired	H000001
Automatic type FE, see pic				

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Pahoia Public Library

Device Type	Location	ScanID : S/N	Service	Time	Date
PASSED					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C.	Children Center	G09871229 G09871229	Annual Service	1:42:46 PM	12/17/24
Fire Extinguisher, 5 Lbs, A.B.C.	Front door	F99800924 F99800924	Annual Service	1:37:42 PM	12/17/24
Fire Extinguisher, 5 Lbs, A.B.C.	Staff office	XH760499	6yr Maintenance	2:04:03 PM	12/17/24

FAILED/OTHER

Fire					
Fire Extinguisher, 16#, A.B.C.	Book Drop	H000001	Condemned	9:09:17 PM	12/17/24



SERVICE SUMMARY

Generated by: BuildingReports.com

The Service Summary section provides an overview of the services performed in this report.

Building: Pahoa Public Library

Device Type	Service	Quantity
PASSED		
Fire Extinguisher, A.B.C., 5 Lbs	6yr Maintenance	1
Fire Extinguisher, A.B.C., 5 Lbs	Annual Service	2
Total		3
FAILED/OTHER		
Fire Extinguisher, A.B.C., 16#	Condemned	1
Total		1
Grand Total		4

FIRE EXTINGUISHER MAINTENANCE REPORT

Generated by: BuildingReports.com

This report provides details on the Hydrostatic Test and Maintenance/Breakdown dates for fire extinguishers. Items that will need either of these services at any time in the next two years are displayed. Items are grouped together by year for budgeting purposes.

Building: Pahoa Public Library

ScanID	Location	Serial #	Hydro	Breakdown	Mfr Date
DUE IN 2026					
Breakdown/Maintenance					
Fire Extinguisher, A.B.C., 5 Lbs					
F99800924	Front door	F99800924	12/17/24	12/17/26	01/01/20
G09871229	Children Center	G09871229	12/17/24	12/17/26	01/01/20
XH760499	Staff office		12/17/24	12/17/26	01/01/20
Total Fire Extinguisher, A.B.C., 5 Lbs:					3

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Paho Public Library

Device or Type	Category	% of Inventory	Quantity
Fire Extinguisher	Fire	100.00%	4

Type	Qty	Model #	Description	Manufacture Date
------	-----	---------	-------------	------------------

IN SERVICE - 3 YEARS TO 5 YEARS

Amerex

Fire Extinguisher	3	B402	A.B.C.	01/01/2020
-------------------	---	------	--------	------------

IN SERVICE - 25 YEARS OR OLDER

ADX Automatic FE

Fire Extinguisher	1	1000 series	A.B.C.	01/01/1994
-------------------	---	-------------	--------	------------