



2024

Mountain View Public Library


18-1235 Volcano Hwy
Mountain View, HI 96771
808-968-2322

Building Contact: Jayne Hen
Title: Site Contact

Company: Guardian Fire, LLC
Contact: Jared David-Chapman
Title: Inspector

Inspection Date: Dec 27, 2024

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Mountain View Public Library 18-1235 Volcano Hwy Mountain View, HI 96771 United States of America	Contact: Jayne Hen
	Phone: 808-968-2322
	Fax:
	Mobile:
	Email: facilities@librarieshawaii.org

Inspection Performed By

Guardian Fire, LLC 73-5577 KAUHOLA ST KAILUA KONA, HI 96740-2642 United States of America	Inspector: Jared David-Chapman
	Phone: 808-896-4515
	Fax:
	Mobile:
	Email: jared@gfhawaii.com


Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	5	100.00%	5	100.00%	3	60.00%	2	40.00%
Totals	5	100%	5	100.00%	3	60.00%	2	40.00%

Certification

Company: Guardian Fire, LLC

Inspector: Jared David-Chapman



Signed: Dec 27, 2024

Building: Mountain View Public Library

Contact: Jayne Hen



Signed: Dec 27, 2024

DISCREPANCY REPORT

Generated by: BuildingReports.com

The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Building: Mountain View Public Library

Items listed for Recall or Replacement/Upgrade

Device Type	Manufacturer	Model Number	Date	Qty
-------------	--------------	--------------	------	-----

No items found during this inspection.

Discrepancies

ScanID	Location	Problem	Reference
FIRE			
Fire Extinguisher, A.B.C. automatic dry FE, 5 Lbs			
95541552	Book drop	Date Expired	NFPA 10 4.4.2
Fire Extinguisher, Carbon Dioxide, 10 Lbs			
95541541	Storage closet/elec. rm.	Date Expired	NFPA 10 4.4.2

Code References

NFPA 10 4.4.2	Any fire extinguisher that can no longer be serviced in accordance with the manufacturer's maintenance manual is considered obsolete and shall be removed from service.
----------------------	---

PROPOSED SOLUTIONS REPORT

Generated by: BuildingReports.com

The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.

Building: Mountain View Public Library

ScanID	Location	Solution	Model #	Cost	Fix
FIRE					
Fire Extinguisher, A.B.C. automatic dry FE, 5 Lbs					
95541552	Book drop	Add New		T/M	<input type="checkbox"/>
Fire Extinguisher, Carbon Dioxide, 10 Lbs					
95541541	Storage closet/elec. rm.	Add New		T/M	<input type="checkbox"/>

Total: T/M **PO #:** (none)

NOTES & RECOMMENDATIONS

Generated by: BuildingReports.com

The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.

Building: Mountain View Public Library

Note	Device Type	Location	Comment	ScanID
FIRE				
1	Fire Extinguisher	Book drop	Date Expired	95541552
Automatic dry FE				

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Mountain View Public Library

Device Type	Location	ScanID : S/N	Service	Time	Date
PASSED					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C.	Back door	Z720737	Annual Service	11:41:46 AM	12/27/24
Fire Extinguisher, 5 Lbs, A.B.C.	Outside book drop	XH761379	6yr Maintenance	11:57:30 AM	12/27/24
Fire Extinguisher, 5 Lbs, A.B.C.	Side door	WY797560	Annual Service	11:38:46 AM	12/27/24
FAILED/OTHER					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C. automatic dry FE	Book drop	95541552	Condemned	11:35:36 AM	12/27/24
Fire Extinguisher, 10 Lbs, Carbon Dioxide	Storage closet/elec. rm.	95541541	Condemned	12:04:59 PM	12/27/24

SERVICE SUMMARY

Generated by: BuildingReports.com

The Service Summary section provides an overview of the services performed in this report.

Building: Mountain View Public Library

Device Type	Service	Quantity
PASSED		
Fire Extinguisher, A.B.C., 5 Lbs	6yr Maintenance	1
Fire Extinguisher, A.B.C., 5 Lbs	Annual Service	2
Total		3
FAILED/OTHER		
Fire Extinguisher, Carbon Dioxide, 10 Lbs	Condemned	1
Fire Extinguisher, A.B.C. automatic dry FE, 5 Lbs	Condemned	1
Total		2
Grand Total		5

FIRE EXTINGUISHER MAINTENANCE REPORT

Generated by: BuildingReports.com

This report provides details on the Hydrostatic Test and Maintenance/Breakdown dates for fire extinguishers. Items that will need either of these services at any time in the next two years are displayed. Items are grouped together by year for budgeting purposes.

Building: Mountain View Public Library

ScanID	Location	Serial #	Hydro	Breakdown	Mfr Date
DUE IN 2019					
Hydrostatic Test					
Fire Extinguisher, Carbon Dioxide, 10 Lbs					
95541541	Storage closet/elec. rm.		12/27/14		12/27/89
Total Fire Extinguisher, Carbon Dioxide, 10 Lbs:					1

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Mountain View Public Library

Device or Type	Category	% of Inventory	Quantity
Fire Extinguisher	Fire	100.00%	5

Type	Qty	Model #	Description	Manufacture Date
------	-----	---------	-------------	------------------

IN SERVICE - 10 YEARS TO 15 YEARS

Amerex

Fire Extinguisher	1		A.B.C.	12/27/2010
-------------------	---	--	--------	------------

IN SERVICE - 15 YEARS TO 25 YEARS

Amerex

Fire Extinguisher	1		A.B.C.	12/27/2005
Fire Extinguisher	1		A.B.C.	12/27/2004

IN SERVICE - 25 YEARS OR OLDER

Amerex

Fire Extinguisher	1		Carbon Dioxide	12/27/1989
-------------------	---	--	----------------	------------

Buckeye

Fire Extinguisher	1		A.B.C. automatic dry FE	12/27/1976
-------------------	---	--	-------------------------	------------