



2025



Kealakekua Public Library


81-6619 Mamalahoa Hwy
Kealakekua, HI 96750
808-323-7587

Building Contact: Merri Fernandez
Title: Site Contact

Company: Guardian Fire, LLC
Contact: Jared David-Chapman
Title: Inspector

Inspection Date: Jan 7, 2025

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Kealakekua Public Library 81-6619 Mamalahoa Hwy Kealakekua, HI 96750 United States of America	Contact: Merri Fernandez
	Phone: 808-323-7587
	Fax:
	Mobile:
	Email: facilities@librarieshawaii.com

Inspection Performed By

Guardian Fire, LLC 73-5577 KAUHOLA ST KAILUA KONA, HI 96740-2642 United States of America	Inspector: Jared David-Chapman
	Phone: 808-896-4515
	Fax:
	Mobile:
	Email: jared@gfhawaii.com

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	3	100.00%	3	100.00%	2	66.67%	1	33.33%
Totals	3	100%	3	100.00%	2	66.67%	1	33.33%

Certification

Company: Guardian Fire, LLC
Inspector: Jared David-Chapman

Building: Kealakekua Public Library
Contact: Merri Fernandez



Signed: Jan 7, 2025

DISCREPANCY REPORT

Generated by: BuildingReports.com

The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Building: Kealakekua Public Library

Items listed for Recall or Replacement/Upgrade

Device Type	Manufacturer	Model Number	Date	Qty
-------------	--------------	--------------	------	-----

No items found during this inspection.

Discrepancies

ScanID	Location	Problem	Reference
--------	----------	---------	-----------

FIRE

Fire Extinguisher, A.B.C., 10 Lbs

95541525	Book drop automatic/manual FE	Date Expired	NFPA 10 4.4.2
----------	-------------------------------	--------------	---------------

Code References

NFPA 10 4.4.2	Any fire extinguisher that can no longer be serviced in accordance with the manufacturer's maintenance manual is considered obsolete and shall be removed from service.
----------------------	---

PROPOSED SOLUTIONS REPORT

Generated by: BuildingReports.com

The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.

Building: Kealakekua Public Library

ScanID	Location	Solution	Model #	Cost	Fix
FIRE					
Fire Extinguisher, A.B.C., 10 Lbs					
95541525	Book drop automatic/manual FE	Add New		T/M	<input type="checkbox"/>

Total: T/M **PO #:** (none)

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Kealakekua Public Library

Device Type	Location	ScanID : S/N	Service	Time	Date
PASSED					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C.	Back area	C32517987	Annual Service	1:39:34 PM	01/07/25
Fire Extinguisher, 5 Lbs, A.B.C.	Front door	XM408785	6yr Maintenance	1:27:50 PM	01/07/25
FAILED/OTHER					
Fire					
Fire Extinguisher, 10 Lbs, A.B.C.	Book drop automatic /manual FE	95541525	Condemned	1:34:50 PM	01/07/25

SERVICE SUMMARY

Generated by: BuildingReports.com

The Service Summary section provides an overview of the services performed in this report.

Building: Kealakekua Public Library

Device Type	Service	Quantity
PASSED		
Fire Extinguisher, A.B.C., 5 Lbs	6yr Maintenance	1
Fire Extinguisher, A.B.C., 5 Lbs	Annual Service	1
Total		2
FAILED/OTHER		
Fire Extinguisher, A.B.C., 10 Lbs	Condemned	1
Total		1
Grand Total		3

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Kealakekua Public Library

Device or Type	Category	% of Inventory	Quantity
Fire Extinguisher	Fire	100.00%	3

Type	Qty	Model #	Description	Manufacture Date
IN SERVICE - 5 YEARS TO 10 YEARS				
Amerex				
Fire Extinguisher	1		A.B.C.	01/07/2016
IN SERVICE - 15 YEARS TO 25 YEARS				
Amerex				
Fire Extinguisher	1		A.B.C.	01/07/2005
IN SERVICE - 25 YEARS OR OLDER				
Porta-Matic				
Fire Extinguisher	1		A.B.C.	01/07/1988