



2024



Laupahoehoe Public Library


35-2065 Old Mamalahoa Hwy
Laupahoehoe, HI 96764
808-962-2229

Building Contact: Amber Collins
Title: Site Contact

Company: Guardian Fire, LLC
Contact: Jared David-Chapman
Title: Inspector

Inspection Date: Dec 27, 2024

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Laupahoehoe Public Library 35-2065 Old Mamalahoa Hwy Laupahoehoe, HI 96764 United States of America	Contact: Amber Collins
	Phone: 808-962-2229
	Fax:
	Mobile:
	Email: Rusmala.cruz@librarieshawaii.org

Inspection Performed By

Guardian Fire, LLC 73-5577 KAUHOLA ST KAILUA KONA, HI 96740-2642 United States of America	Inspector: Jared David-Chapman
	Phone: 808-896-4515
	Fax:
	Mobile:
	Email: jared@gfhawaii.com


Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	7	100.00%	3	42.86%	3	100.00%	0	0.00%
Totals	7	100%	3	42.86%	3	100.00%	0	0.00%

Certification

Company: Guardian Fire, LLC

Inspector: Jared David-Chapman



Signed: Dec 27, 2024

Building: Laupahoehoe Public Library

Contact: Amber Collins



Signed: Dec 27, 2024

NOTES & RECOMMENDATIONS

Generated by: BuildingReports.com

The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.

Building: Laupahoehoe Public Library

Note	Device Type	Location	Comment	ScanID
FIRE				
1	Fire Extinguisher	2nd Entrance	Passed	I-35184328
Add disposal fee				
2	Fire Extinguisher	2nd I/s Staff Work Rm.	Passed	I-35184349
Add disposal fee				
3	Fire Extinguisher	2nd O/s Humanities Rm.	Passed	I-35184362
Add disposal fee				

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Laupahoehoe Public Library

Device Type	Location	ScanID : S/N	Service	Time	Date
PASSED					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C.	2nd Entrance	I-35184328 NU-380882	Install	1:13:10 PM	12/27/24
Fire Extinguisher, 5 Lbs, A.B.C.	2nd I/s Staff Work Rm.	I-35184349 RH-019846	Install	1:14:19 PM	12/27/24
Fire Extinguisher, 5 Lbs, A.B.C.	2nd O/s Humanities Rm.	I-35184362 PX-145235	Install	1:15:58 PM	12/27/24
UNTESTED					
Fire					
Fire Extinguisher, 5 Lbs, A.B.C.	2nd I/s Humanities Rm. Stairs	VR560135 VR560135			
Fire Extinguisher, 5 Lbs, A.B.C.	Parking I/s AC Rm.	F447203 F447203			
Fire Extinguisher, 5 Lbs, A.B.C.	Parking I/s Electrical Rm.	H02439587 H02439587			
Fire Extinguisher, 5 Lbs, A.B.C.	Parking I/s Maintenance Shop	H07325780 H07325780			

SERVICE SUMMARY

Generated by: BuildingReports.com

The Service Summary section provides an overview of the services performed in this report.

Building: Laupahoehoe Public Library

Device Type	Service	Quantity
PASSED		
Fire Extinguisher, A.B.C., 5 Lbs	Install	3
Total		3
UNTESTED		
Fire Extinguisher, A.B.C., 5 Lbs		4
Total		4
Grand Total		7

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Laupahoehoe Public Library

Device or Type	Category	% of Inventory	Quantity
Fire Extinguisher	Fire	100.00%	7

Type	Qty	Model #	Description	Manufacture Date
------	-----	---------	-------------	------------------

IN SERVICE - 90 DAYS - 1 YEAR

Ansul

Fire Extinguisher	1	A400-98	A.B.C.	01/01/2024
Fire Extinguisher	1	A402-99	A.B.C.	01/01/2024
Fire Extinguisher	1	A500-97	A.B.C.	01/01/2024

IN SERVICE - 2 YEARS TO 3 YEARS

Amerex

Fire Extinguisher	1	AB500-03	A.B.C.	01/01/2022
Fire Extinguisher	1	B402	A.B.C.	01/01/2022

IN SERVICE - 3 YEARS TO 5 YEARS

Amerex

Fire Extinguisher	1	B402	A.B.C.	01/01/2021
-------------------	---	------	--------	------------

IN SERVICE - 15 YEARS TO 25 YEARS

Amerex

Fire Extinguisher	1	AB500-09	A.B.C.	11/21/2009
-------------------	---	----------	--------	------------