

State of Hawaii
DEPARTMENT OF LAND AND NATURAL RESOURCES
ENGINEERING DIVISION
1151 Punchbowl Street, Room 221
Honolulu, Hawaii 96813

ADDENDUM NO. 1

TO

Job No: C00BO91C
Anuenue Fisheries Research Center
Annex Facility Improvements – Phase 1B (Sewer Improvements)
Sand Island, Oahu, Hawaii

This addendum as issued shall become part of the Contract Documents for the subject project. The bid documents, plans, and specifications shall be amended as follows:

GENERAL INFORMATION

A pre-bid conference and site visit was held on May 8, 2026, at 10:30 am and 10:40 respectively at the project site. The meeting agenda and sign-in sheet are attached.

QUESTIONS AND ANSWERS

1. QUESTION 1: *To Bidders (Page ii) states "To be eligible to submit a bid, the Bidder must possess a valid State of Hawaii Contractor's license classification "B". However, the work being performed falls under Classification "A". Please revise the requirement to Classification "A"*

RESPONSE: Revised.

2. QUESTION 2: The bid bond form included in the solicitation General Conditions seems to be outdated. Please advise if the typical bid bond form can be used.

RESPONSE: Please refer to Section 2.5 of the DLNR Interim General Conditions dated October 1994.

3. QUESTION 3: Please clarify the bid due date. HiePro shows May 27, 2026, at 2:00 pm. However, at the pre-bid conference it was noted that the bid date is May 26, 2026, 2:00 pm.

RESPONSE: The offer due date is May 27, 2026, at 2:00 pm.

4. QUESTION 4: Our grinder pump offers significant advantages in robustness and ease of maintenance by using a grinder pump rather than a progressive cavity pump with an attached grinder. We recently replaced an E-One station on the island that had persistent clogging issues with our system, and the end user is very satisfied with the performance. Franklin Electric (FELE) has done much more throughout the US.

RESPONSE: We are not reviewing or approving alternative products at this stage of the procurement process. Bidders should prepare their bids in accordance with the project specifications and plans. Alternative products may be submitted for review only after a contract has been awarded to the lowest responsive, responsible bidder.

CONSTRUCTION PLANS

(REPLACE with the attached revised drawings)

<u>Drawing No.</u>	<u>Revision Description</u>
C103	Revised & updated civil plan and profile.
C501	System revised from single grinder pump to duplex grinder pump system
E101	Revised & updated electrical plan and electrical notes
E201	Revised & updated connection diagram, elevation, panel schedule, and electrical notes.

CONSTRUCTION SPECIFICATIONS

<u>Specification No.</u>	<u>Revision Description</u>
NOTICE TO BIDDERS	Revised license classification from “B” to “A”.
02734	Revised this section to include the duplex system with two pumps instead of the one pump that was previously stated.

Engineering Division



Dina U. Lau
Acting Chief Engineer