



NOTES:

1. All fencing material including gate hardware shall be galvanized steel.
2. Posts, braces, and gate frames shall be schedule 40 (standard weight) pipe. Sizes specified are outside diameter.
3. Gate shall be provided with provisions for padlocking.
4. Corner fittings for gate frames may be used in lieu of welding.
5. For 3' or 4' high gate, eliminate all horizontal bracing and attach truss rod to top of adjacent line post. Chain link fabric shall be 2" mesh, 11 gage.
6. Gate shall have knuckled setvage top and bottom.
7. Top of concrete footing shall be crowned to shed water.

TYPICAL PERSONNEL GATE

SCALE: 3/8" = 1'-0"

R-20

STANDARD
DETAILS

TYPICAL SINGLE GATE

SEPTEMBER 1984

SCALE: 3/8" = 1'-0"

COUNTY OF KAUAI
CITY & COUNTY OF HONOLULU
COUNTY OF MAUI
COUNTY OF HAWAII

