

IFB-26-HHL-009 East Hawaii Hilo District Office Improvements Additional Questions:

1. How much runtime would you like on the battery backup system?  
6 hours
2. Do you want a dedicated security monitor included?  
No, PC or Phone
3. Do you want mobile access to the cameras?  
Yes, domestically located servers only
4. Please confirm whether Axis cameras are acceptable for the CCTV system, or if DHHL has a specific required camera manufacturer, model, or platform they would like us to use. The drawings appear to identify camera locations and coverage intent, but I did not see a specified CCTV manufacturer or model listed in the documents.  
Domestically located servers only
5. Will any analytics be required for loitering, trespassing, or after-hours activity in the identified areas? The analytics can be to report to a monitoring service to dispatch security or police if loitering or trespassing is triggered on cameras.  
No
6. Are there any security-related areas outside of CCTV that DHHL would like included?  
No
7. Clarify access control. “The abbreviation list includes ACS, but I do not see card readers, controllers, electrified locks, REX, or door contacts on the drawings. Is access control actually part of the intended scope, or is this limited to mechanical door hardware?”  
No card readers
8. Are there any required security tie-ins with the fire alarm system?  
No, FA is being disconnected from the school system
9. Do you want professional security monitoring for burglary/intrusion alarms?  
No
10. Would DHHL like us to include monitored smoke/heat detection through our panels?  
No
11. Who will be responsible for camera wiring, the security contractor or electrical contractor?  
Security Team
12. Please confirm we are allowed to run free wire inside the structures where feasible to minimize cost, or does all wiring need to be in conduit/raceway?

Wiring not requiring conduits per code do not need conduit inside of structures. All exterior wires need conduits for aesthetic purposes. All work needs to be coordinated with the other trades.

13. Will this scope be bid through a prime contractor, or is Blackhawk allowed to bid the security scope separately as a lump sum?

Prime Contractor

14. If the security scope must go through the prime, who should Blackhawk submit pricing to?

Prime Contractor

15. Will we be working with any firewall, VLAN, or IT restrictions that could affect outside/mobile access?

Yes, domestic servers only

16. Since there is no existing security system onsite, would DHHL like an intrusion alarm system or monitoring using camera system included as an option?

No

17. Please confirm the existing network connectivity at each building be used for the outer building cameras?

Yes

18. Should Blackhawk provide a base proposal matching the drawings and a separate alternate for the expanded coverage discussed onsite?

Base Proposal only

19. Are there any preferred camera manufacturers, NVR/VMS platforms, or State-approved equipment standards we need to follow?

Domestically located servers only

20. Are there any NDAA compliance requirements for the CCTV equipment?

Assume Yes

21. Should pricing include training for DHHL staff on live view, playback, export, and mobile access?

Yes

22. Should the proposal include labeling, as-built camera layout, IP/device schedule, and closeout documentation?

Yes

23. What is the expected installation schedule, and will the security work need to be coordinated around other trades during construction?

Determined by Prime Contractor, yes.