

**STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HARBORS**

**ADDENDUM NO. 1
FOR
KAHULUI HARBOR, REPLACE FIRE RISERS AT PIER 1 SHED,
MAUI, HAWAII
JOB S30254**

May 29, 2026

The following is provided for your information:

A. RESPONSE TO REQUEST FOR INFORMATION (RFI / QUESTIONS)

1. The attached **RESPONSES TO REQUEST FOR INFORMATION** is provided for your information.

Please acknowledge receipt of this **ADDENDUM NO. 1** by recording the date of its receipt in the space provided on **PAGE P-4** of the PROPOSAL.



NIKO G. SALVADOR
Harbors Engineering Program Manager

RESPONSE TO REQUEST FOR INFORMATION (RFI / QUESTIONS)

Questions for Solicitation: B26002764 / S30254 –
Kahului Harbor, Replace Fire Risers at Pier 1 Shed, Maui, Hawaii
05/29/2026

1. Are you requiring union labor for this project, or can both union and non-union contractors participate?
 - A. – Contractors are not restricted by union status.

2. What is the size pipe for the FDC connection? One drawing shows 2 rider, are both being replaced?
 - A. – Plan details show an 8” connection main line connection. Conditions on-site should be verified before ordering materials and beginning work.
– Yes. Two fire risers, both on the same side of the shed, will be replaced.

3. On submittals package, exactly what is wanted? Cut sheets for all material?
 - A. – Yes, submittal documents must show the materials of all parts and components being used to verify their compliance with the specifications, along with other compliance documents required by Harbor Construction Engineer. Further submittal information and details will be discussed during the pre-construction meeting.