STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HARBORS

ADDENDUM NO. 1
FOR
GRADING CORAL FLATS,
KAWAIHAE HARBOR, HAWAII ISLAND
PROJECT NO. S50214

June 12, 2026

The following is provided for information.

A. PRE-BID MEETING MINUTES

1. The **PRE-BID MEETING MINUTES** and **ATTENDANCE SHEET** are provided for information.

B. RESPONSES TO REQUESTS FOR INFORMATION (RFI)

1. The attached **RESPONSES TO REQUESTS FOR INFORMATION** are provided for information.

Please acknowledge receipt of this **ADDENDUM NO. 1** by recording the date of its receipt in the space provided on the **PAGE P-4** of the Proposal.

NIKO G. SALVADOR
Harbors Engineering Program Manager

STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HARBORS

PRE-BID MEETING MINUTES

Date: June 1, 2026
Time: 10:00 AM HST

Location: Microsoft Teams web-link and teleconference call

Project: Grading Coral Flats, Kawaihae Harbor,
Hawaii Island
Job S50214

Subject: Voluntary Pre-Bid Meeting

I. INTRODUCTIONS

1. Introduction of participants.

II. IMPORTANT ITEMS

1. This meeting is to clarify general questions only. If there is a conflict between what was stated in this meeting and the bid documents, the bid documents shall govern. Any significant changes will be issued through an addendum. A copy of the meeting minutes will be issued to all attendees.

2. Deadline for questions is 2:00 p.m. HST on June 8, 2026.

All questions must be submitted through HIePRO.

3. Proposals are due on June 22, 2026 at 2:00 p.m. HST.

4. The scope of work consists of mass grading of coral flats at Kawaihae Harbor, Hawaii Island.

5. The estimated cost is estimated to be between $1,000,000 and $1,700,000.

6. Bidders must possess a valid State of Hawaii General Engineering Contractor's "A" license at the time of bidding.

7. This is a State funded project, Prospective bidders are reminded to comply with all State requirements.

8. Entry Requirements: Transportation Worker Identification Credentials (TWIC) will be required for the Contractor's personne

9. The project duration is 90 calendar days from the Notice to Proceed (NTP) date.

10. Liquidated damages are as follows:

    - $300 per calendar day for failure to complete the project within 90 calendar days.

11. The Proposal Schedule must be completely filled out even if the proposed cost is $0 for a line item. Incomplete proposals will be considered irregular.

12. A NPDES permit is required for the project. HDOT-Harbors is in the process of submitting the permit for approval. The work shall not start until the Notice of General Permit Coverage (NGPC) is received.

III. QUESTIONS

1. Is Grading Permit required?

Answer: Grading Permit is not required in this project.

2. Is there an archeological study or report?

Answer: We will verify and provide answer in the addendum.

PRE-BID MEETING ATTENDANCE SHEET

Project Name: Grading Coral Flats, Kawaiahe Harbor, Hawaii Island

Project No.: S50214

Location: Microsoft Teams web-link and teleconference call

Date: June 1, 2026 10:00 AM

NAME	COMPANY	E-MAIL	PHONE
Emmanuel Legaspi	HDOT Harbors	emmanuel.b.legaspi@hawaii.gov	
Neal Fukumoto	WRSA	neal@wrsasolutions.com	
Kerry Willocks	Willocks Const. Corp.	kerry@willocks.com	
Glenn Kobayashi	Isemoto Contr. Co.	glennk@isemotocontracting.com	

RESPONSES TO REQUEST FOR INFORMATION (RFI)

1. **Are you requiring union labor for this project, or can both union and non-union contractors participate?**

Response: Union labor is not required for this project.

2. **Is there a pre-bid meeting attendees list?**

Response: Yes, the Pre-bid Meeting Attendance Sheet is attached to this addendum.

3. **Please confirm Grading Permit is not required as discussed at the Prebid Meeting.**

Response: Confirming Grading permit is not required for this project.

4. **Is there an Archeological Report/Study? Is so, could we get a copy?**

Response: There is the 2011 Archeological Literature Review and Field Inspection For the Kawaihae Harbor Project, Kawaihae 1 and 2 for a grading project on the coral flats area where nothing of archeological significance was observed.

5. **Is there a Geological Report? Is so, could we get a copy?**

Response: None.

6. **Specifications state all excavated materials and materials on site are expected to be suitable for final grading. Please confirm the materials does not need to be process/crushed.**

Response: Confirming said materials do not need to be processed/crushed.

7. **Please confirm the NPDES has been acquired. Could we get a copy?**

Response: NPDES permit has not been acquired at this time. Copy will be provided upon receipt of the approved permit.

8. **Will a TWIC Card be required to work in this area?**

Response: Yes

9. **Confirm the 95% compaction will be visually determined since we will be unable to complete a proctor of the existing material.**

Response: Compaction shall follow Section 13.2 of the Specificatoins.

10. **Please confirm grassing as noted in the Temporary Water Pollution, Dust and Erosion Control specifications will not be required.**

Response: Confirming grassing will not be required.

11. **Please confirm all the concrete piles, wooden piles, chassis and containers will be removed fom the entire jobsite prior to the start of work**

Response: Confirming all the concrete piles, wooden piles, chassis and containers will be removed from the entire jobsite prior to the start of work

12. **Please confirm all rental agreements for plots on the jobsite will be resolved prior to the start of work.**

Response: Confirming all rental agreements for plots on the jobsite will be resolved prior to the start of work.