



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 122602939
Customer ID: EMET50
Customer PO:
Project ID:

Attention: EMET EMET - Environmeteo Services 94-520 Ukee Street Suite A Waipahu, HI 96797 Project: 2604149 / Foreign Trade Zone 9 Warehouse	Phone: (808) 671-8383 Fax: (808) 671-7979 Received Date: 04/21/2026 10:45 AM Analysis Date: 04/23/2026 Collected Date: 04/17/2026
--	--

Test Report: Asbestos Analysis of Bulk Materials via AHERA Method 40CFR 763 Subpart E Appendix E supplemented with EPA 600/R-93/116 using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
149-FTZ9-1A1 <small>122602939-0001</small>	Asphalt Paving Aisle 9	Black Non-Fibrous Homogeneous		98% Non-fibrous (Other)	2% Chrysotile
149-FTZ9-1A2 <small>122602939-0002</small>	Asphalt Paving Aisle 9	Black Non-Fibrous Homogeneous		98% Non-fibrous (Other)	2% Chrysotile
149-FTZ9-1A3 <small>122602939-0003</small>	Asphalt Paving Aisle 9	Black Non-Fibrous Homogeneous		98% Non-fibrous (Other)	2% Chrysotile
149-FTZ9-1B1- Concrete <small>122602939-0004</small>	Concrete Pillar	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
149-FTZ9-1B2- Coating/ Concrete <small>122602939-0005</small> <i>Materials are inseparable.</i>	Concrete Pillar	Gray/Green Non-Fibrous Heterogeneous		100% Non-fibrous (Other)	None Detected
149-FTZ9-1B3- Coating/ Concrete <small>122602939-0006</small> <i>Materials are inseparable.</i>	Concrete Pillar	Gray/Green Non-Fibrous Heterogeneous		100% Non-fibrous (Other)	None Detected
149-FTZ9-1C1 <small>122602939-0007</small>	Asphalt Paving Bay 67	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	<1% Chrysotile
149-FTZ9-1C2 <small>122602939-0008</small>	Asphalt Paving Bay 67	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
149-FTZ9-1C3 <small>122602939-0009</small>	Asphalt Paving Bay 67	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	<1% Chrysotile

Analyst(s) _____

Jose Madril (3)
Nezzarae Choate (6)

Erica Furphy, Asbestos Supervisor
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Phoenix, AZ NVLAP Lab Code 200811-0, AZ0937, CO AL-19027, CA 2761, TX 300484, HI L-14-004, LA 05113

Initial report from: 04/24/2026 12:30:34