

STATE OF HAWAII
DEPARTMENT OF DEFENSE
HAWAII ARMY NATIONAL GUARD

PROJECT TITLE:

**CA-202505-C BUILDING 46 MEDCOM RENOVATIONS, KALAELOA,
OAHU, STATE OF HAWAII'I, DEPARTMENT OF DEFENSE, HAWAII**

ADDENDUM NO. 1

The items listed hereinafter are hereby made a part of the contract for the above-mentioned project and shall govern the work taking precedence over previously issued contract documents governing the items mentioned. Receipt of this addendum is to be acknowledged on page OF-8 of the proposer's packet.

CLARIFICATIONS:

1. Hazmat Reports have been attached to the end of this Addendum as Attachment #1.
2. Fire Alarm Shop Drawings have been attached to the end of this Addendum as Attachment #2.
3. Specification Section 08111 – Hollow Metal Doors and Frames has been attached to the end of this Addendum as Attachment #3.
4. Requests for Substitution

SECTION/ITEM	SPECIFIED BRAND	SUBSTITUTE OR ALTERNATE	VARIANT FEATURES	RESPONSE
07210, 2.01, A.	ASTM C 1289, Type I or II 20 PSI, R-20 minimum	SOPRA Iso Insulation, ASTM C 1289 Type I or II, 20 PSI, R-20 minimum	None	No exceptions taken to proposed substitution, provided it meets the specifications. Subject to further review and comments during the

				formal submittal process.
07210, 2.01, B.	Tapered EPS Foam 2.0 lb. density, ASTM C 578 Type I	SOPRA Iso TAPERED Insulation, ASTM C 1289	1. PolyIso	No exceptions taken to proposed substitution, provided it meets the specifications. Subject to further review and comments during the formal submittal process.
07531, 1.04, C.1.,2. & 3.	15-Year NDL warranty with 105 MPH Wind Rider	20-Year NDL with 105 MPH Wind Rider (SOPREMA Platinum Warranty)	1. Exceeds specified warranty term	No exceptions taken to proposed substitution, provided it meets the specifications. Subject to further review and comments during the formal submittal process.
07531, 2.02, A.1.	60 MIL TPO Membrane ASTM D 6878	SOPREMA SENTINEL P-150 60 MIL PVC Membrane, ASTM 4434, Type III	1. PVC Membrane	No exceptions taken to proposed substitution, provided it meets the specifications. Subject to further review and comments during the formal

				submittal process.
10161, 2.01, A. (Solid Plastic Toilet Partitions and Urinal Screens)		Hiny Hiders Toilet Partitions	None	Proposed substitution will only be approved on condition that color selection is fire-tested. Subject to further review and comments during the formal submittal process.

5. Questions and Answers have been answered on HlePro and are listed below.

1. There are no bid documents posted (plans & specs.) or link to download. How do we get these?

I apologize. Plans and Specs will be uploaded to HlePRO on Monday, August 3. In the meantime, they can be viewed here: <https://dod.hawaii.gov/hieng/plans-and-specs/building-46-medcom-renovations-kalaeloa-oahu-hiarng/>

2. The drawings indicate hollow metal doors and frames; however, no corresponding specification section was found in Division 08. Please provide the applicable specifications for the hollow metal doors and frames, including material, gauge, finish, and fire-rating requirements.

Response: Specification Section 08111 - Hollow Metal Doors and Frames has been added.

3. Is there a Buy America(n) requirement for this project? If so, are fixtures complying with TAA (Trade Agreement) acceptable?

Response: There is no Buy America Act requirement for this project.

4. Is Pollution Insurance coverage required for this project per Item 3D of Attachment S5?

Response: Pollution insurance will be required only if Bid Alt #7 Roof Replacement is awarded.

5. During our review of the contract documents, the scope of work for the solid surface material was identified; however, no specific information was found regarding the manufacturer, product type, color, or grade. Please provide the requested information.

Response: Manufacturer: Corian Solid Surface, Color: Silver Birch, or approved equal. For more information, please refer to SECTION 06220 - SOLID SURFACE COUNTERTOPS

6. Please provide the company name of the Fire Alarm vendor / contact for this building

Response: Refer to attached fire alarm shop drawings for the recently installed system.

7. Specification Section 01715 references an Asbestos/Lead/Hazardous Material Survey, but the report for the existing roof is missing. Please provide the hazardous material survey for the existing roof.

Response: Refer to prior hazardous material surveys included with this addendum.

8. Locations and quantities of concrete deficiencies are not shown on the drawings. Please provide the scope quantities for the spall and crack repair details referenced in section 03930 and structural drawings. Additionally, please confirm whether this work is included in the base bid or under the alternates.

Response: Grid F7 on Plan S-102 Base Bid

9. Per specification section 01715, the state's hazardous material survey indicates that asbestos was not detected for this project. Please confirm if this understanding is correct.

Response: Previous testing performed by the state has determined that the roof contains asbestos. Work related to asbestos is included in Section 13280. Refer to prior hazardous material surveys included with this addendum.

10. Door details indicate a bevel at door openings, but existing CMU and concrete walls are not currently beveled. Please clarify if beveling is required for new, existing, or all wall openings.

Response: Beveling is not required. Door opening edge profiles/details to match existing conditions.

11. Per sheet A-601, all new hollow metal door frames show a standard 2" face width; however, the existing door frames have a 4" header face. Please confirm if 2" frame

faces are required or if 4" header faces should be provided to match existing conditions.

Response: Provide 4" header faces to match existing conditions.

12. The room finish schedule indicates existing ceilings are to remain, except where replacement is specified. Please clarify if new ductwork, cable trays, piping, and related utilities are to be exposed and surface-mounted below the existing drywall ceilings where ceilings are retained.

Response: All work will be concealed above ceilings. Ceilings shall be replaced wherever necessary to install new MEP work, and all associated costs for repair and finishing shall be included under the base bid. Extent of ceiling replacement is expected to be coordinated between subcontractors and all costs included.

13. Can a contractor holding only a C-13 license be the general contractor on this job?

Response: No. An A or B license is required to be the prime bidder.

14. What is the difference between base bid electrical and the additive alternatives listed for electrical?

Response: Refer to description of base bid items shown on E-001, and additive alternates listed on following sheets. In general the base bid is to include all electrical panels, metering switchboard, and feeders, as well as any branch circuiting associated with the new layouts (also called out as "Base Bid" on drawings).

15. Should base bid include finishes for ceiling, painting, and flooring?

Response: Refer to response to Question #19.

16. The painting and flooring on the first and second floors of Building 46 look fairly new. What is the scope for painting and flooring?

Response: Refer to response to Question #19.

17. Where is the elevator?

Response: Elevator is identified throughout drawings. Refer to floor plans with room tag "ELEV".

18. Is the HVAC system to be a Toshiba brand?

Response: Basis of design manufacturer has been provided on mechanical schedules, but the contractor is not restricted from using other brands of matching performance

characteristics.

19. What is the difference between the base bid and the three additive alternatives for architecture on the three floors?

Response:

Base Bid:

First Floor Rooms:

- 106 Lactation Room, 108 Storage, 110 Electrical 1A, 112 Telecom, 114 Mechanical
- 015 Corr 1D
- 115 Women's RR, 116 Janitor, 117 Men's RR
- 107 Pad Check-Out, 109 Pad Office, 111 Med Records, 113 Storage, 016 Corridor 1E
- Wall demolition/refinishing for existing wall demising existing Offices 105/107 and Offices 106/108
- Opening/repair of chase walls to install any MEP utilities
- Construction of associated walls/finishes in the specific vicinity of the plumbing fixtures at 118 EKG, 119 IMMZ/CHOL A, 121 IMMZ/CHOL B, Dental 122, 123, 124, 125, 127 Hearing Room

Second Floor Rooms:

- 214 Jan
- 215 Women's RR
- 218 Men's RR
- 024 Corridor 2D

Third Floor Rooms:

- 314 Men's RR
- 315 Jan
- 319 Women's RR
- 320 Men's Shower, 321 Women's Shower

Additive Alternate:

1st floor , 2nd floor and 3rd floor architectural demo and new work, all work not included in base bid.

20. Is the existing HVAC system and concrete pad below to remain, since they are fairly new?

Response: Refer to mechanical drawings for scope associated with the existing equipment and pads.

21. How are ceilings to remain if ductwork is running through it? Do the ceilings need to be replaced?

Response: Refer to response to Question #12 above.

22. Is the roof substrate a concrete slab?

Response: Yes, roof substrate is concrete slab.

23. How many new water heaters are to be installed?

Response: Refer to equipment schedules on plumbing drawings.

24. Since existing CMU walls are to remain, can controllers and other devices be surface-mounted?

Response: Yes, where devices are shown on existing CMU walls, the devices and conduits will be surface mounted. Where devices are installed on new walls, the devices and conduits shall be recessed.

25. Will the project be awarded based on the total of Base Bid and all Additive Alternates or is it possible that some Additive Alternates may be included but not others?

Response: Project will be awarded according to the best interests of the State.

CA-202505-C Addendum

Attachment #1


BLDG 46 HAZMAT Report

Inventory Pages 1-18

Summary Pages 19-27

BUILDING 46

Asbestos Inventory



BUILDING SUMMARY

This report presents and discusses the results of a comprehensive asbestos-containing material (ACM) inspection conducted in building 46, Enlisted Men's Barracks, located on Naval Air Station (NAS) Barbers Point, Oahu, Hawaii. The inspection was conducted on 30 August 1994 by an USEPA Accredited Inspector.

Building 46 is a three story 25,806 square foot concrete structure with a built-up roof. Interior finish materials consisted of vinyl and carpet floorings; concrete block, concrete, and gypsum board walls; and concrete ceilings. The year of construction was reported as 1957. The photographs for homogeneous areas 4 - 7 are not available for this building.

Seven homogeneous areas of suspect ACM were identified during the inspection. As indicated by the material bulk sample analysis results, one homogeneous area was found to contain asbestos. The ACM identified for the building was:

- (4) tar, black located on the roof AC supports (identified as part of CTO 0126)

Two homogeneous areas assumed to contain asbestos included:

- (5) roof core
- (7) tar, black and insulation located around roof AC unit

The ACM and assumed ACM identified for building 46 were all noted to be in good condition on the day of the inspection and as such, the materials pose a low potential for exposing building occupants to airborne asbestos fibers. However, if the ACM or assumed ACM become damaged or disturbed, the potential for exposing building occupants to airborne asbestos fibers would increase.

BUILDING #: 46
 BUILDING AREA (SF): 25,806
 YEAR BUILT: 1957
 BUILDING TYPE: HOUSING
 LOCATION: WAS BARBERS POINT, HI

BUILDING DATA (INCLUDING COST ESTIMATES) FOR SUSPECT
 ASBESTOS-CONTAINING AND ASSUMED ASBESTOS-CONTAINING MATERIAL (ACM)

FACILITY RATING SCORE: P07

HA NO	ASBESTOS CONTAINING	ADCM* RATING SCORE	HA DESCRIPTION	HA LOCATION	IA QUANTITY	DEGREE OF FRIABILITY	RECOMMENDED RESPONSE ACTIONS	INITIAL REPAIR COST	ANNUAL O&M COST	REMOVAL COST	REPLACE- MENT COST	REMOVAL & REPLACE- MENT COST
4	YES	P07	TAR, BLACK	ROOF AC SUPPORTS	3,000 LF	NON	O&M PROGRAM	\$0	\$1,800	\$54,000	\$36,000	\$90,000
5	ASSUMED	P09	ROOF CORE	ROOF	8,600 SF	NON	O&M PROGRAM	\$0	\$1,634	\$64,500	\$17,200	\$81,700
7	ASSUMED	P07	TAR, BLACK AND INSULATION	AROUND ROOF AC UNIT	300 LF	NON	O&M PROGRAM	\$0	\$180	\$5,400	\$3,600	\$9,000
SUBTOTAL								\$0	\$3,614	\$123,900	\$56,800	\$180,700
ADDITIONAL ASBESTOS REMOVAL/REPAIR COST @ 40%**								\$0		\$49,560	\$11,360	\$49,560
ADDITIONAL REPLACEMENT COSTS @ 20%***												
TOTAL ASBESTOS ABATEMENT COSTS								\$0	\$3,614	\$173,460	\$68,160	\$241,620

KEY: CT = CEILING TILE
 INS = INSULATION
 PI = PIPE INSULATION
 EA = EACH
 LF = LINEAR FEET
 SF = SQUARE FEET
 O&M = OPERATIONS AND MAINTENANCE
 HA = HOMOGENEOUS AREA
 PFI = PIPE FITTING INSULATION
 N/A = NOT APPLICABLE
 ACM = ASBESTOS-CONTAINING MATERIAL

* SEE PART 4, NEESA FORM 3900/52

** 40% MARK-UP FOR ADDITIONAL ASBESTOS REMOVAL/REPAIR COSTS (CONTINGENCY, DESIGN, AIR MONITORING AND CONSTRUCTION ADMINISTRATION FEES)

*** 20% MARK-UP FOR ADDITIONAL REPLACEMENT COSTS (CONTINGENCY, DESIGN, AND CONSTRUCTION ADMINISTRATION FEES)

NOTE: THESE BUDGETARY COSTS ARE TYPICALLY BASED ON A PER BUILDING PROJECT BASIS. IN THE CASE OF A BUILDING WITH A SMALL AMOUNT OF ACM, SEVERAL BUILDINGS SHOULD BE COMBINED INTO A SINGLE PROJECT FOR COST EFFECTIVENESS.

ASBESTOS INVENTORY SUMMARY BUILDING NUMBER 46

HOMOGENEOUS AREAS:

NUMBER	HOMOGENEOUS AREA DESCRIPTION	ASBESTOS	
		(Y/N/A)	LOCATION (ROOM NO.)
1	FLOOR TILE/MASTIC, 12' X 12", GREY	N	
2	GYPSUM BOARD, WALLS	N	
3		N	
4	TAR, BLACK	Y	ROOF AC SUPPORTS
5	ROOF CORE	A	ROOF
6	FELT PAPER, BLACK	N	
7	TAR, BLACK AND INSULATION	A	AROUND ROOF AC UNIT

YEAR BUILT: 1957

BUILDING TYPE: HOUSING

(Training, Housing, Research, Medical, Utilities, Production, Supply)

BUILDING SIGNIFICANCE: ESSENTIAL

(Critical, Essential, Non-Essential)

ASBESTOS PROGRAM MANAGER: CARY SPARKS


CODE: L20

PHONE: 808-684-0728

(DSN/Commercial)

INSPECTOR NAME: WILLIAM GARIBAY

PHONE: 423-481-8002

SIGNATURE: 

EPA ACCREDITATION NUMBER: 1392

SURVEY DATE: 08/30/94

ASBESTOS HOMOGENEOUS AREA SUMMARY

HOMOGENEOUS AREA NUMBER: 4

Homogeneous Area Description: TAR, BLACK

SECTION I

ASBESTOS (Y/N/A):	Y	FRIABLE (Y/N):	N	Building #:	46
Quantity (SF/LF):	3,000 LF	Public Access (Y/N):	N	Room #:	(see Section II #7)

O&M Action(s): O&M PROGRAM

RATING
SCORE

PD 7

SECTION II

1. Condition:	Significant Damage	Damage	Potential Damage
Base Score:	20	15	10

2. Quantity (Square Feet/Linear Feet): 3,000 LF Diameter in Inches (if applicable)

Quantity Range:	Greater than 5000	Less than 5000	Less than 1000
		Greater than 1000	Greater than 0
Multiplier:	1.2	1.1	1.0

3. Friability:	High	Moderate	Low	Non
Multiplier:	1.4	1.1	1.0	0.5

4. Exposure Potential:	Accessible and Occupied	Inaccessible and Likely to Expose	Accessible and Non-Occupied	Inaccessible and Not Likely to Expose
Multiplier:	1.5	1.3	1.0	0.5

5. Number of Persons Exposed: 0

Range:	Greater than 100	Less than 100	Less than 40	Less than 10
		Greater than 40	Greater than 10	Greater than 0
Multiplier:	1.4	1.3	1.2	1.1

6. Recommended action(s): O&M PROGRAM
(isolate area, restrict access, clean area, O&M, encapsulate, enclose, remove)

7. Homogeneous area location: ROOF AC SUPPORTS

8. Asbestos form: TROWELLED-ON
(blanket, molded, preformed, aircell, sheet, sprayed-on, trowelled-on, loose fill)

9. Building Significance:	Critical	Essential	Non-essential
Multiplier:	1.2	1.1	0.5

SECTION III (Complete after laboratory analysis)

Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)	Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)
00	12	CHRYSTOTILE			

11. Percentage of Asbestos (largest percentage asbestos from sample analysis): 12

Range:	Greater than 40%	Less than 40%	Less than 15%
	or Assumed	Greater than 15%	Greater than 1%
Multiplier:	1.2	1.1	1.0
			0

10.0

1.1

0.5

1.0

1.1

1.1

1.0

Multiply the Base Score by the number in each box to get the numeric scores. Place the "Alpha" condition (SD,D,PD) in front of the number (e.g. SD67, D36).

Attachment (2)

THIS FORM MAY BE COPIED

NEESA FORM 3900/52 (05-92)

ASBESTOS HOMOGENEOUS AREA SUMMARY

HOMOGENEOUS AREA NUMBER: 5

Homogeneous Area Description: ROOF CORE

SECTION I

ASBESTOS (Y/N/A):	A	FRIABLE (Y/N):	N	Building #:	46
Quantity (SF/LF):	8,600 SF	Public Access (Y/N):	Y	Room #:	(see Section II #7)

O&M Action(s): O&M PROGRAM

RATING
SCORE

PD 9

SECTION II

1. Condition:	Significant Damage	Damage	Potential Damage
Base Score:	20	15	10

2. Quantity (Square Feet/Linear Feet): 8,600 SF Diameter in Inches (if applicable)

Quantity Range:	Greater than 5000	Less than 5000	Less than 1000
		Greater than 1000	Greater than 0
Multiplier:	1.2	1.1	1.0

3. Friability:	High	Moderate	Low	Non
Multiplier:	1.4	1.1	1.0	0.5

4. Exposure Potential:	Accessible and Occupied	Inaccessible and Likely to Expose	Accessible and Non-Occupied	Inaccessible and Not Likely to Expose
Multiplier:	1.5	1.3	1.0	0.5

5. Number of Persons Exposed: 2

Range:	Greater than 100	Less than 100	Less than 40	Less than 10
		Greater than 40	Greater than 10	Greater than 0
Multiplier:	1.4	1.3	1.2	1.1

6. Recommended action(s): O&M PROGRAM
(isolate area, restrict access, clean area, O&M, encapsulate, enclose, remove)

7. Homogeneous area location: ROOF

8. Asbestos form: SHEET
(blanket, molded, preformed, aircell, sheet, sprayed-on, trowelled-on, loose fill)

9. Building Significance:	Critical	Essential	Non-essential
Multiplier:	1.2	1.1	0.5

SECTION III (Complete after laboratory analysis)

10. Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)	Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)

11. Percentage of Asbestos (largest percentage asbestos from sample analysis): ASSUMED

Range:	Greater than 40%	Less than 40%	Less than 15%
	or Assumed	Greater than 15%	Greater than 1%
Multiplier:	1.2	1.1	1.0
			Less than 1%
			0

10.0

1.2

0.5

1.0

1.1

1.1

1.2

Multiply the Base Score by the number in each box to get the numeric scores. Place the "Alpha" condition (SD,D,PD) in front of the number (e.g. SD67, D36).

Attachment (2)

THIS FORM MAY BE COPIED

NEESA FORM 3900V52 (05-92)

ASBESTOS HOMOGENEOUS AREA SUMMARY

HOMOGENEOUS AREA NUMBER: 7

Homogeneous Area Description: TAR, BLACK AND INSULATION

SECTION I

ASBESTOS (Y/N/A):	A	FRIABLE (Y/N):	N	Building #:	46
Quantity (SF/LF):	300 LF	Public Access (Y/N):	Y	Room #:	(see Section II #7)

O&M Action(s): O&M PROGRAM

SECTION II

1. Condition:	Significant Damage	Damage	Potential Damage
Base Score:	20	15	10

2. Quantity (Square Feet/Linear Feet): 300 LF Diameter in Inches (if applicable)

Quantity Range:	Greater than 5000	Less than 5000	Less than 1000
		Greater than 1000	Greater than 0
Multiplier:	1.2	1.1	1.0

3. Friability:	High	Moderate	Low	Non
Multiplier:	1.4	1.1	1.0	0.5

4. Exposure Potential:	Accessible and Occupied	Inaccessible and Likely to Expose	Accessible and Non-Occupied	Inaccessible and Not Likely to Expose
Multiplier:	1.5	1.3	1.0	0.5

5. Number of Persons Exposed: 2

Range:	Greater than 100	Less than 100	Less than 40	Less than 10
		Greater than 40	Greater than 10	Greater than 0
Multiplier:	1.4	1.3	1.2	1.1

6. Recommended action(s): O&M PROGRAM
(isolate area, restrict access, clean area, O&M, encapsulate, enclose, remove)

7. Homogeneous area location: AROUND ROOF AC UNIT

8. Asbestos form: TROWELLED-ON
(blanket, molded, preformed, aircell, sheet, sprayed-on, trowelled-on, loose fill)

9. Building Significance:	Critical	Essential	Non-essential
Multiplier:	1.2	1.1	0.5

SECTION III (Complete after laboratory analysis)

Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)	Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)

11. Percentage of Asbestos (largest percentage asbestos from sample analysis): ASSUMED

Range:	Greater than 40% or Assumed	Less than 40% Greater than 15%	Less than 15% Greater than 1%	Less than 1%
Multiplier:	1.2	1.1	1.0	0

RATING
SCORE

PD 7

10.0

1.0

0.5

1.0

1.1

1.1

1.2

Multiply the Base Score by the number in each box to get the numeric scores. Place the "Alpha" condition (SD,D,PD) in front of the number (e.g. SD67, D36).

Attachment (2)

THIS FORM MAY BE COPIED

NEESA FORM 3900/52 (05-92)

ASBESTOS HOMOGENEOUS AREA SUMMARY

HOMOGENEOUS AREA NUMBER: 9

Homogeneous Area Description: ROOF CORE

SECTION I

ASBESTOS (Y/N/A):	A	FRIABLE (Y/N):	N	Building #:	48
Quantity (SF/LF):	8,600 SF	Public Access (Y/N):	Y	Room #:	(see Section II #7)

O&M Action(s): O&M PROGRAM

RATING
SCORE

PD 9

SECTION II

1. Condition:	Significant Damage	Damage	Potential Damage
Base Score:	20	15	10

2. Quantity (Square Feet/Linear Feet): 8,600 SF Diameter in Inches (if applicable)

Quantity Range:	Greater than 5000	Less than 5000	Less than 1000
		Greater than 1000	Greater than 0
Multiplier:	1.2	1.1	1.0

3. Friability:	High	Moderate	Low	Non
Multiplier:	1.4	1.1	1.0	0.5

4. Exposure Potential:	Accessible and Occupied	Inaccessible and Likely to Expose	Accessible and Non-Occupied	Inaccessible and Not Likely to Expose
Multiplier:	1.5	1.3	1.0	0.5

5. Number of Persons Exposed: 2

Range:	Greater than 100	Less than 100	Less than 40	Less than 10
		Greater than 40	Greater than 10	Greater than 0
Multiplier:	1.4	1.3	1.2	1.1

6. Recommended action(s): O&M PROGRAM
(isolate area, restrict access, clean area, O&M, encapsulate, enclose, remove)

7. Homogeneous area location: ROOF

8. Asbestos form: SHEET
(blanket, molded, preformed, aircell, sheet, sprayed-on, trowelled-on, loose fill)

9. Building Significance:	Critical	Essential	Non-essential
Multiplier:	1.2	1.1	0.5

SECTION III (Complete after laboratory analysis)

Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)	Sample Number	Total % Asbestos	Type(s) of Asbestos (chrysotile, amosite, etc.)

11. Percentage of Asbestos (largest percentage asbestos from sample analysis): ASSUMED

Range:	Greater than 40% or Assumed	Less than 40%	Less than 15%	Less than 1%
Multiplier:	1.2	1.1	1.0	0

10.0

1.2

0.5

1.0

1.1

1.1


1.2

Multiply the Base Score by the number in each box to get the numeric scores. Place the "Alpha" condition (SD,D,PD) in front of the number (e.g. SD67, D36).

Attachment (2)

THIS FORM MAY BE COPIED

NEESA FORM 3900/52 (05-92)




FIRST FLOOR

NOT TO SCALE

SAMPLE LOCATIONS

CTO 152 ASBESTOS INSPECTION
 NAVAL AIR STATION - BARBERS POINT
 OAHU, HAWAII
 BUILDING # 46
 ENLISTED MEN'S BARRACKS

BA-46-2-02




SECOND FLOOR

CTO 152 ASBESTOS INSPECTION
NAVAL AIR STATION - BARBERS POINT
OAHU, HAWAII
BUILDING # 46
ENLISTED MEN'S BARRACKS

SAMPLE LOCATIONS


NOT TO SCALE



NOT TO SCALE

SAMPLE LOCATIONS

CTO 152 ASBESTOS INSPECTION
 NAVAL AIR STATION - BARBERS POINT
 OAHU, HAWAII
 BUILDING # 46
 ENLISTED MEN'S BARRACKS



THIRD FLOOR

NOTE: THE FOLLOWING WAS IDENTIFIED AS ACM:

- TAR, BLACK LOCATED ON AC SUPPORTS


THE FOLLOWING WERE ASSUMED AS ACM:

- ROOF CORE
- TAR, BLACK LOCATED AROUND ROOF AC UNIT


CTO 152 ASBESTOS INSPECTION
 NAVAL AIR STATION - BARBERS POINT
 OAHU, HAWAII
 BUILDING # 46
 ENLISTED MEN'S BARRACKS

ROOF


NOT TO SCALE




Homogeneous Area Number: 1
 Description: floor tile/mastic 12" x 12", grey



Homogeneous Area Number: 2
 Description: gypsum board, walls



Homogeneous Area Number: 3
Description: baseboard mastic



Homogeneous Area Number: 4
Description: tar, black

BULK ASBESTOS ANALYSIS REPORT

Client Name : OGDEN

Street Address : 1009 Commerce Park Drive

City, State, Zip : Oak Ridge, TN 37830

Location/Description: BARBERS PIONT - 46

Analytical Method: EPA/NVLAP PLM Method (Federal Register --40 CFR Ch. 1, Pt. 763, Subpt. F, Appendix A, 7/1/91).

Client Project # : CT00152

ENTEK Project# : 95152-61

Analysis Date : 10/25/94

SAMPLE NUMBER ENTEK Sample #	ASBESTOS FIBER CONTENT (Composite total and individual layer percentages)					NON-ASBESTOS CONTENT	
						Fibrous	Non-fibrous Binder
BA-46-1-01 94B3820	TOTAL ASBESTOS = <u>Not detected</u>					Fibrous = N.D.	Binder approx.=100%
Remarks	FLOOR TILE/GLUE						
Homogeneity	layered						
Condition **	non-friable						
Color / texture	blue						
Layer/area #	Vol. %	chrysotile	amosite	tremolite/act.		Fibrous	Non-fibrous Binder
1	99%	N.D.	N.D.	N.D.			vinyl binder/carbonate binder
2	1%						
BA-46-1-02 94B3821	TOTAL ASBESTOS = <u>Not detected</u>					Fibrous = N.D.	Binder approx.=100%
Remarks	FLOOR TILE/GLUE						
Homogeneity	layered						
Condition **	non-friable						
Color / texture	blue						
Layer/area #	Vol. %	chrysotile	amosite	tremolite		Fibrous	Non-fibrous Binder
1	99%	N.D.	N.D.	N.D.			vinyl binder/carbonate binder
2	1%						
BA-46-2-01 94B3822	TOTAL ASBESTOS = <u>Not detected</u>					Fibrous =8%	Binder approx.=92%
Remarks	WALLBOARD						
Homogeneity	homogenous						
Condition **	non-friable						
Color / texture	white						
Layer/area #	Vol. %	chrysotile	amosite	tremolite		Fibrous Materials:	Non-fibrous Binder:
1	100%	N.D.	N.D.	N.D.		cellulose/fiberglass	gypsum
BA-46-2-02 94B3823	TOTAL ASBESTOS = <u>Not detected</u>					Fibrous =5%	Binder approx.=96%
Remarks	PAINT/TAPING/WALLBOARD						
Homogeneity	layered						
Condition **	non-friable						
Color / texture	white						
Layer/area #	Vol. %	chrysotile	amosite	tremolite		Fibrous Materials:	Non-fibrous Binder:
1	2%	N.D.	N.D.	N.D.			paint
2	8%						calcium carbonate
3	90%					cellulose	gypsum
BA-46-2-03 94B3824	TOTAL ASBESTOS = <u>Not detected</u>					Fibrous =5%	Binder approx.=95%
Remarks	PAINT/TAPING/WALLBOARD						
Homogeneity	layered						
Condition **	non-friable						
Color / texture	white						
Layer/area #	Vol. %	chrysotile	amosite	tremolite		Fibrous Materials:	Non-fibrous Binder:
1	2%	N.D.	N.D.	N.D.			paint
2	4%						calcium carbonate
3	94%					cellulose	gypsum

Authorized Signature: *Quetta G. Williams*

Date: 10/25/94

Data Entry Initials : CJC

When a sample is non-homogenous or layered, each non-homogenous area is analyzed separately.

* An asterisk (*) in front of sample# indicates one layer or non-homogenous area within the sample contains greater than 1% asbestos.

** "Condition" is the sample friability observed during sample receipt and preparation and is not necessarily indicative of the source material.

* Samples reported as Not detected are non-asbestos containing according to limitations and resolution of the PLM method.

* Samples reported as less than 1% (<1%) should be considered "asbestos-containing" unless multiple sample analyses are all less than 1%.

BULK ASBESTOS ANALYSIS REPORT

Client Name : OGDEN

Street Address : 1009 Commerce Park Drive

City, State, Zip : Oak Ridge, TN 37830

Location/Description: BARBERS PIONT - 46

Analytical Method: EPA/NVLAP PLM Method (Federal Register --40 CFR Ch. 1, Pt. 763, Subpt. F, Appendix A 7/1/91).

Client Project # : CT00152

ENTEK Project# : 95152-61

Analysis Date : 10/25/94

SAMPLE NUMBER ENTEK Sample #	ASBESTOS FIBER CONTENT (Composite total and individual layer percentages)				NON-ASBESTOS CONTENT	
					Fibrous	Non-fibrous Binder
BA-46-3-01 94B3825	TOTAL ASBESTOS = <u>Not detected</u>				Fibrous =20 %	Binder approx.=80%
	Remarks	BROWN GLUE/BACKING				
	Homogeneity	layered				
	Condition **	non-friable				
	Color / texture	brown resinous/rubber-like				
	Layer/area #	Vol.%	chrysotile	amosite	tremolite	
	1	80%	N.D.	N.D.	N.D.	
	2	20%				
					Fibrous Materials:	Non-fibrous Binder:
					cellulose	binder

Authorized Signature: [Signature] Date: 10/25/94 Data Entry Initials: CJC

When a sample is non-homogenous or layered, each non-homogenous area is analyzed separately.

* An asterisk (*) in front of the sample# indicates one layer or non-homogenous area within the sample contains greater than 1% asbestos.

** "Condition" is the sample friability observed during sample receipt and preparation and is not necessarily indicative of the source material.

• Samples reported as Not detected are non-asbestos containing according to limitations and resolution of the PLM method.

• Samples reported as less than 1% (<1%) should be considered "asbestos-containing" unless multiple sample analyses are all less than 1%.

NVLAP Accreditation #: 1455

ASBESTOS BULK SAMPLING LOG

NAS BARBERS POINT

THE SZARAS COMPANIES

PAGE 1 of 1

DATE SAMPLES COLLECTED: December 3, 1993

BUILDING NUMBER 46		BUILDING NAME BEQ		BUILDING DESCRIPTION 3 Story	
TSC PROJECT NUMBER 868		TSC INSPECTOR J. Brodewolf, T. Maietta		TSC LABORATORY ID No. 120793H	
SAMPLE ID NO	SAMPLE LOCATION / DESCRIPTION	ANALYTICAL RESULTS	FRIABLE	CONDITION	AMOUNT
	INTERIOR:				
BA1203-17	1st floor Vending room Gray 12" x 12" floor tile	None detected	No	Good	500 sq. ft.
	EXTERIOR:				
BA1203-18	Roof Core sample	None detected	No	Good	20,000 sq. ft.
BA1203-19	Roof Roof access Black felt paper	None detected	No	Good	8 sq. ft.
BA1203-20	Roof Concrete supports for A/C unit Black tar	12% Chrysotile	No	Good	3,000 sq. ft.
BA1203-21	Roof Around A/C unit insulation Black tar and insulation	None detected	No	Good	300 sq. ft.

It is assumed that anywhere the above identified asbestos containing building materials are found in the building, that those materials also contain asbestos and should be treated as such.

Yes or No refers to a sample of similar material and is considered either positive or negative for asbestos content as per the referred sample in the Sample Location/Description column.

SAMPLE MATRIX

DW DRINKING WATER
 WW WASTEWATER
 GW GROUNDWATER
 SW SURFACE WATER
 SO SOIL

OL C
 AR AIR
 SL SLUDGE
 HZ HAZARDOUS

A.D. # _____
 CLIENT OGDEN 7403820
 ADDRESS 1009 Commerce Park Drive
Suite No. 100
 CITY Oak Ridge
 STATE TN ZIP 37830
 PHONE NO (615) 481-8002

PROJECT NUMBER CTO 0152
 PROJECT NAME Asbestor Inspection
 SAMPLED BY Bill Garibay
 SAMPLE SITE Barbers Point

PURCHASE ORDER NUMBER

110190152

PROJECT MANAGER (person to receive data)

Bill Garibay

REQUEST FAX DATA TO _____ (FAX #)

REQUEST VERBAL RESULTS BY _____ (DATE)

NEED DATA PACKAGE BY _____ (DATE)

QUALITY CONTROL REPORTING LEVEL

0 1 2 3 4 (circle one)

EXTRA COPIES OF REPORT

SAMPLE I.D.	DATE	TIME	MATRIX
BA-46-1-01	8-26-94	N/A	N/A
-1-02			
-2-01			
-2-02			
-2-03			
✓ -3-01			

TOTAL NUMBER OF BOTTLES/CONTAINERS

RELINQUISHED BY:

Andrea Brunner

DATE

9-12-94

RECEIVED BY:

Scott G. Giddell / Entek

DATE

10/24/94

TIME

SPECIAL INSTRUCTIONS:

PRIOR AUTHORIZATION IS REQUIRED FOR RUSH PROJECTS

TURN AROUND TIME

(NORMAL) ☒ 2 WEEKS

RUSH: ☐ 24 HOURS ☐ 48 HOURS ☐ 72 HOURS ☐ 1 WEEK

SAMPLE DISPOSAL INSTRUCTIONS

ASBESTOS INVENTORY SUMMARY
BUILDING NUMBER 46

HOMOGENEOUS AREAS:

NUMBER:	HOMOGENEOUS AREA DESCRIPTION	ASBESTOS (Y/N/A)	LOCATION (ROOM NO.)
1	FLOOR TILE/MASTIC, 12" X 12", GREY	N	
2	GYPSUM BOARD, WALLS	N	
3	BASEBOARD MASTIC	N	
4	TAR, BLACK	Y	ROOF AC SUPPORTS
6	FELT PAPER, BLACK	N	
7	TAR, BLACK AND INSULATION	N	AROUND ROOF AC UNIT
8	BUILT-UP ROOF (SEVERAL LAYERS), BLACK GRAVEL	Y	ROOF OVERHANG AT ENTRANCE
9	DUCT INSULATION, GREY	N	ROOF HVAC DUCT SYSTEM

YEAR BUILT: 1957

BUILDING TYPE: BEQ
(Training, Housing, Research, Medical, Utilities, Production,

BUILDING SIGNIFICANCE: ESSENTIAL
(Critical, Essential,

ASBESTOS PROGRAM MANAGER: CARY SPARKS CODE: L20

PHONE: 808-684-0728
(DSN/Commercial)

INSPECTOR NAME: MELISSA HELTON, TRAVIS STANLEY, ABBAS SAM, BRIAN SARIANO, RICK GIACONIA

PHONE: 423-481-8002

SIGNATURE:

EPA ACCREDITATION NUMBER: 1392

SURVEY DATE: (INTERIOR) 6/4/1998 (ROOF)

Attachment (2)

THIS FORM MAY BE COPIED

COMMENTS SECTION:

Contractor: OGDEN ENVIRONMENTAL AND ENERGY SVCS

Phone Number: 423-481-8002

Address: 161 MITCHELL ROAD, OAK RIDGE, TN 37830

Additional Information: ADDITIONAL COMMENTS ABOUT BLDG #: 46

BUILDING #: 46
 BUILDING AREA (SF): 25,806
 YEAR BUILT: 1957
 BUILDING TYPE: BEQ
 LOCATION: NAS BARBERS POINT, HI

BUILDING DATA (INCLUDING COST ESTIMATES) FOR SUSPECT
 ASBESTOS-CONTAINING AND ASSUMED ASBESTOS-CONTAINING MATERIALS (ACM)

FACILITY RATING SCORE: PD7

ACM* HA ASBESTOS RATING HA NO CONTAINING SCORE DESCRIPTION LOCATION HA HA DEGREE OF FRIABILITY RECOMMENDED RESPONSE ACTIONS INITIAL REPAIR COST ANNUAL O+M COST REMOVAL COST REPLACE-MENT COST REMOVE +

4	Y	PD	7	\$6,000	\$18,000	TAR, BLACK	ROOF AC SUPPORTS	3000	SF	NO&M PROGRAM	\$0	\$3,600	\$12,000
---	---	----	---	---------	----------	------------	------------------	------	----	--------------	-----	---------	----------

8	Y	PD	3	\$435	\$1,718	BUILT-UP ROOF (SEVERAL LAYERS), BLACK GRAVEL	OVERHANG AT ENTRANCE		229	SF	NO&M PROGRAM	\$0	\$0
---	---	----	---	-------	---------	--	----------------------	--	-----	----	--------------	-----	-----

SUBTOTAL													
											\$0	\$4,035	\$13,718
											\$0	\$5,487	\$6,458
											\$0	\$1,292	\$20,176
											\$0	\$19,205	\$5,487
											\$0	\$7,750	\$1,292
											\$0	\$26,954	\$26,954

KEY: CT = CEILING TILE
 INS = INSULATION
 PI = PIPE INSULATION
 EA = EACH
 LF = LINEAR FEET
 SF = SQUARE FEET
 O+M = OPERATIONS AND MAINTENANCE
 HA = HOMOGENEOUS AREA
 PFI = PIPE FITTING INSULATION
 N/A = NOT APPLICABLE
 ACM = ASBESTOS CONTAINING MATERIAL

* SEE PART 4, NEESA FORM 3900/52
 ** 40% MARK-UP FOR ADDITIONAL ASBESTOS REMOVAL/REPAIR COSTS (CONTINGENCY, DESIGN, AIR MONITORING AND CONSTRUCTION ADMINISTRATION FEES)
 *** 20% MARK-UP FOR ADDITIONAL REPLACEMENT COSTS (CONTINGENCY, DESIGN, AND CONSTRUCTION ADMINISTRATION FEES)
 NOTE: THESE BUDGETARY COSTS ARE TYPICALLY BASED ON A PER BUILDING PROJECT BASIS. IN THE CASE OF A BUILDING WITH A SMALL AMOUNT OF ACM, SEVERAL BUILDINGS SHOULD BE COMBINED INTO A SINGLE PROJECT FOR COST EFFECTIVENESS.



Homogeneous Area: 4

Description: Tar, black



Homogenous Area: 8

Description: Built-up roof (several layers), black gravel




Homogeneous Area: 4

Description: Tar, black



Homogenous Area: 8

Description: Built-up roof (several layers), black gravel



NOTE: THE FOLLOWING WAS IDENTIFIED AS ACM:
 • TAR, BLACK LOCATED ON AC SUPPORTS

LEGEND



BUILT-UP ROOF (SEVERAL LAYERS). BLACK GRAVEL

CTO 228 ASBESTOS INSPECTION
 NAVAL AIR STATION - BARBERS POINT
 OAHU, HAWAII
 BUILDING # 46
 ENLISTED MEN'S BARRACKS

ROOF

NOT TO SCALE

CA-202505-C Addendum

Attachment #2

BLDG 46 Fire Alarm Shop Drawings

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

FIRE ALARM SYSTEM

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

PROJECT INFORMATION

- THIS SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE SPECIFICATIONS AND STANDARDS APPROVED BY THE AUTHORITY HAVING JURISDICTION.
- ALL DEVICES AND APPLIANCES SHALL BE LOCATED AND MOUNTED SO THAT ACCIDENTAL OPERATION OR FAILURE IS NOT CAUSED BY VIBRATION OR JARRING.
- EQUIPMENT SHALL BE INSTALLED IN LOCATIONS WHERE CONDITIONS DO NOT EXCEED THE VOLTAGE, TEMPERATURE, AND HUMIDITY LIMITS SPECIFIED IN THE MANUFACTURER'S PUBLISHED INSTRUCTIONS.
- THE SECONDARY POWER SUPPLY SHALL AUTOMATICALLY PROVIDE POWER TO THE PROTECTED PREMISES SYSTEM WITHIN 10 SECONDS WHENEVER THE PRIMARY POWER SUPPLY FAILS TO PROVIDE THE MINIMUM VOLTAGE REQUIRED FOR PROPER OPERATION.
- INITIATING DEVICES OF THE MANUAL OR AUTOMATIC TYPE SHALL BE SELECTED AND INSTALLED SO AS TO MINIMIZE NUISANCE AND UNINTENTIONAL ALARMS.
- ALL FIRE ALARM DEVICES SHALL COMPLY FULLY WITH ALL A.D.A. REQUIREMENTS.
- REQUIRED SIGNALS SHALL NOT BE LOST, INTERRUPTED, OR DELAYED BY MORE THAN 10 SECONDS AS A RESULT OF THE PRIMARY POWER FAILURE.

APPLICABLE CODES & STANDARDS

JURISDICTIONS WITHIN THE STATE MAY HAVE AMENDMENTS TO THE STATE ADOPTED CODE. CHECK WITH THE LOCAL JURISDICTION AUTHORITY FOR MORE DETAILS.
HAWAII BUILDING CODE 2021(IBC 2021) NOT AMENDED
HAWAII RESIDENTIAL CODE 2021(IRC 2021) NOT AMENDED
HAWAII ELECTRICAL CODE 2023(NFPA 70, 2023) NOT AMENDED
HAWAII FIRE ALARM CODE 2019(NFPA 72, 2019)
HAWAII FIRE CODE 2021(NFPA 1, 2021) AMENDED
HAWAII FIRE SPRINKLER CODE 2019(NFPA 13, 2019) NOT AMENDED


OCCUPANCY TYPE(S): AHJ:
B Business Group CITY OF HONOLULU (HFD) WITH DOD OVERLAYS

SCOPE OF WORK

REPLACED AN OUTDATED PANEL, DEVICES AND INSTALL A NEW AUTOMATIC AND MANUAL FIRE ALARM SYSTEM AS SHOWN ON DRAWINGS.

ALL WIRING TO BE CLASS A.

AUTOMATIC FIRE ALARM SYSTEM SHALL TRANSMIT THE ALARM, SUPERVISORY AND TROUBLE SIGNALS TO AN APPROVED SUPERVISING STATION. THE SUPERVISING STATION SHALL BE LISTED AS EITHER UUFX OR UUIS UNDERWRITERS LABORATORY OR SHALL MEET THE REQUIREMENTS OF FACTORY MUTUAL RESEARCH APPROVAL STANDARD 3011. SUPERVISION OF SYSTEM AND LEASED TELEPHONE LINES SHALL BE ARRANGED BY THE OWNER.



VICINITY MAP
SCALE: NTS

DEVICE LEGEND

QTY	SYMBOL	DESCRIPTION	PART NUMBER
1	[FACP]	FIRE ALARM CONTROL PANEL W/ 12VDC 18AH BATTERY	ES-1000X IM-12180
2	[BPS]	BOOSTER POWER SUPPLY W/ 12VDC 12AH BATTERY	FL-PS10 IM-12120
1	[EVAC]	EMERGENCY VOICE EVACUATION PANEL W/ CABINET W/ 12VDC 55AH BATTERY	ECC-50/100 BB-55F IM-12550
2	[FAA]	FIRE ALARM ANNUNCIATOR PANEL	ANN-80
3	[LOC]	LOCAL OPERATOR CONSOLE	ECC-LOC
1	[FAC]	CELLULAR DIALER W/ 12VDC 7AH BATTERY	HWF2V-COM IM-1270
1	[DOC]	DOCUMENT BOX	SSU00685
118	[S]	PHOTOELECTRIC SMOKE DETECTOR W/ STANDARD BASE	SD365 B300-6
2	[H]	HEAT DETECTOR W/ STANDARD BASE	H365 B300-6
2	[D]	DUCT SMOKE DETECTOR W/ SMOKE DETECTOR W/ SAMPLING TUBE	D365PL SD365R DST5
2	[RTS]	REMOTE TEST STATION	RTS151KEY
15	[F]	MANUAL PULL STATION	BG-12LX
1	[MM]	MONITOR MODULE	MMF-300
7	[RM]	RELAY MODULE	CRF-300
4	[DH]	DOOR HOLDER	FM998
4	[SS]	SURGE SUPPRESSOR 120V	DTK-120HWLOK
6	[CS]	CEILING MOUNTED STROBE	SCWLED
5	[WS]	WALL MOUNTED SPEAKER/STROBE	SPSWLED
97	[CS]	CEILING MOUNTED SPEAKER/STROBE	SPSCWLED
4	[S]	CEILING MOUNTED SPEAKER	SPCWL

FIRE ALARM WIRE LEGEND

TAG	DESCRIPTION	TYPE	GAUGE	FPL	FPLR	FPLP	THHN	TFFN
A	ADDRESSABLE CIRCUIT (SLC)	UTP SOLID	18 AWG	X	X	X		
B	NOTIFICATION DEVICES (NAC)	2 COND. SOLID	14 AWG	X	X	X	X	X
C	DOOR HOLDER	2 COND. SOLID	14 AWG	X	X	X	X	X
D	ANNUNCIATOR BUS PRIMARY	2 COND. SOLID	18 AWG	X	X	X		
E	LOC BUS CONNECTION	2 COND. SOLID	18 AWG	X	X	X		
H	EXTERNAL AUDIO RISER	2 COND. SOLID	14 AWG	X	X	X	X	X
K	REMOTE TEST STATION	2 COND. SOLID	14 AWG	X	X	X		
L	AUX / POWER (24VDC)	2 COND. SOLID	14 AWG	X	X	X	X	X
S	AUDIO - SPEAKER	STP SOLID	18 AWG	X	X	X		
TR	TRIGGER CIRCUIT	2 COND. SOLID	14 AWG	X	X	X	X	X


NOTE:
ALL CABLES ARE FOR INDOOR INSTALLATIONS. UNDERGROUND CABLE / WIRE MUST BE LISTED FOR INSTALLATION IN WET CONDITION.

	ANNUNCIATION					NOTIFICATION					FIRE SAFETY CONTROL				
	ACTIVATE COMMON ALARM SIGNAL INDICATOR	ACTIVATE AUDIBLE ALARM SIGNAL	ACTIVATE COMMON SUPERVISORY SIGNAL INDICATOR	ACTIVATE AUDIBLE SUPERVISORY SIGNAL	ACTIVATE COMMON TROUBLE SIGNAL INDICATOR	ACTIVATE AUDIBLE TROUBLE SIGNAL	ACTIVATE APPROPRIATE DEVICE LOCATION INDICATOR	ACTIVATE ALL AUDIBLE EVACUATION SIGNALS	ACTIVATE ALL VISIBLE EVACUATION SIGNALS	DISPLAY / PRINT CHANGE OF STATUS	TRANSMIT ALARM SIGNAL TO SUPERVISING STATION	TRANSMIT SUPERVISORY SIGNAL TO SUPERVISING STATION	TRANSMIT TROUBLE SIGNAL TO SUPERVISING STATION	ACTIVATE EMERGENCY COMMUNICATIONS (SPEAKERS / STROBES)	
AREA SMOKE DETECTOR	●	●				●		●	●	●					●
SMOKE DETECTOR - AT FACP		●						●	●	●					●
SMOKE DETECTOR - FOR DOOR RELEASING SERVICE		●						●	●	●					●
SMOKE DETECTOR IN UNITS - SUPERVISORY			●	●				●	●	●		●			●
MANUAL PULL STATION	●	●						●	●	●					●
AREA HEAT DETECTOR		●						●	●	●					●
DUCT DETECTOR AT HVAC FAN - SUPERVISORY			●	●				●	●	●		●			●
ACTIVATION OF EMERGENCY COMMUNICATIONS MESSAGE													●		●
MAIN FLR. ELEV. LOBBY SMOKE DETECTOR	●	●						●	●	●					●
ELEVATOR LOBBY SMOKE DETECTORS (EXCEPT PRIMARY FLR)	●	●						●	●	●					●
ELEVATOR MACHINE ROOM SMOKE DETECTOR	●	●						●	●	●					●
FIRE ALARM PRIMARY/SECONDARY POWER FAILURE				●	●						●				●
FIRE ALARM SYSTEM LOW BATTERY				●	●						●				●
OPEN CIRCUIT				●	●						●				●
GROUND FAULT				●	●						●				●
NOTIFICATION CIRCUIT (NAC) - SHORT				●	●						●				●
LOSS OF COMMUNICATION PATH (INCLUDING CELLULAR DIALER FAILURE)				●	●						●				●

DEVICE MOUNTING HEIGHT REFERENCE

PER NFPA 72

VISUAL APPLIANCE MOUNTING HEIGHT CONSIDERATIONS IN SLEEPING ROOMS
1. MIN DISTANCE IN SLEEPING ROOMS IS 24" (610mm) FROM CEILING TO TOP OF LENS FOR 110CD STROBES WITHIN 16' OF THE PILLOW
2. 177CD STROBES, USED IN SLEEPING ROOMS, CAN BE WITHIN THE 24" (610mm) MINIMUM DISTANCE FROM THE CEILING. THE HIGHER INTENSITY IS TO COMPENSATE FOR A POSSIBLE SMOKE LAYER.



MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HALL
STREET HILO, HI 96720

PROJECT:

DRAWING TITLE:

FIRE ALARM SYSTEM
COVER SHEET.

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025


RE-WORK:

--

SHEET:

01 OF 9 SHEETS

FA-01



- GENERAL NOTES:**
1. ALL CEILINGS ARE ASSUMED TO BE 10' A.F.F., SMOOTH CONSTRUCTION UNLESS NOTED OTHERWISE.
 2. MINIMUM CONDUIT SIZE SHALL BE 3/4"
 3. ALL EXPOSED CONDUITS SHALL BE GRC (GALVANIZED RIGID METALLIC CONDUIT). ALL CONCEALED CONDUITS SHALL BE EMT (ELECTRICAL METALLIC TUBING). ALL UNDERGROUND CONDUIT SHALL BE PVC SCHEDULE 40 UNLESS NOTED.
 4. MINIMUM CIRCUIT PERFORMANCE REQUIREMENTS:
 - IDC - INITIATING DEVICE CIRCUIT SHALL BE CLASS A
 - NAC - NOTIFICATION APPLICATION CIRCUIT SHALL BE CLASS A
 - SLC - SIGNALING LINE CIRCUIT SHALL BE CLASS A
 5. ALL LOOPS SHALL HAVE OUTGOING AND RETURN CONDUCTORS IN SEPARATE CONDUIT.
 6. CLASS A CIRCUITS SHALL BE INSTALLED SUCH THAT THE OUTGOING AND RETURN CONDUCTORS ARE SEPARATED 1 FOOT WHERE THE CABLE IS INSTALLED VERTICALLY AND 4 FEET WHERE THE CABLE IS INSTALLED HORIZONTALLY. THE OUT GOING AND RETURN CIRCUIT CONDUCTORS ARE PERMITTED TO BE INSTALLED IN THE SAME CONDUIT FOR A MAXIMUM DISTANCE OF 10 FEET WHERE THE OUTGOING AND RETURN CONDUCTORS ENTER OR EXIT THE DEVICE.
 7. "T-TAPPING" OF ANY CLASS "A" CIRCUIT IS PROHIBITED.
 8. "ALLOW 3FT. OF CONDUCTOR LENGTH BETWEEN THE 120VAC SURGE SUPPRESSOR AND THE PROTECTED EQUIPMENT. THIS WILL ALLOW THE UNIT TIME TO REACT".

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HALL
STREET HILO, HI 96720

PROJECT:

DRAWING TITLE:

FIRE ALARM SYSTEM
FIRST FLOOR PLAN

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025



RE-WORK:

--

SHEET:

02 OF 9 SHEETS


FA-02



KEY PLAN

SCALE: NTS





- GENERAL NOTES:**
1. ALL CEILINGS ARE ASSUMED TO BE 10' A.F.F., SMOOTH CONSTRUCTION UNLESS NOTED OTHERWISE.
 2. MINIMUM CONDUIT SIZE SHALL BE 3/4"
 3. ALL EXPOSED CONDUITS SHALL BE GRC (GALVANIZED RIGID METALLIC CONDUIT). ALL CONCEALED CONDUITS SHALL BE EMT (ELECTRICAL METALLIC TUBING). ALL UNDERGROUND CONDUIT SHALL BE PVC SCHEDULE 40 UNLESS NOTED.
 4. MINIMUM CIRCUIT PERFORMANCE REQUIREMENTS:
 - IDC - INITIATING DEVICE CIRCUIT SHALL BE CLASS A
 - NAC - NOTIFICATION APPLICATION CIRCUIT SHALL BE CLASS A
 - SLC - SIGNALING LINE CIRCUIT SHALL BE CLASS A
 5. ALL LOOPS SHALL HAVE OUTGOING AND RETURN CONDUCTORS IN SEPARATE CONDUIT.
 6. CLASS A CIRCUITS SHALL BE INSTALLED SUCH THAT THE OUTGOING AND RETURN CONDUCTORS ARE SEPARATED 1 FOOT WHERE THE CABLE IS INSTALLED VERTICALLY AND 4 FEET WHERE THE CABLE IS INSTALLED HORIZONTALLY. THE OUT GOING AND RETURN CIRCUIT CONDUCTORS ARE PERMITTED TO BE INSTALLED IN THE SAME CONDUIT FOR A MAXIMUM DISTANCE OF 10 FEET WHERE THE OUTGOING AND RETURN CONDUCTORS ENTER OR EXIT THE DEVICE.
 7. "T-TAPPING" OF ANY CLASS "A" CIRCUIT IS PROHIBITED.
 8. "ALLOW 3FT. OF CONDUCTOR LENGTH BETWEEN THE 120VAC SURGE SUPPRESSOR AND THE PROTECTED EQUIPMENT. THIS WILL ALLOW THE UNIT TIME TO REACT".

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HALL
STREET HILO, HI 96720

PROJECT:

DRAWING TITLE:

FIRE ALARM SYSTEM
SECOND FLOOR PLAN

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025



RE-WORK:

--

SHEET:


03 OF 9 SHEETS

FA-03





KEY PLAN
SCALE: NTS





- GENERAL NOTES:**
- ALL CEILINGS ARE ASSUMED TO BE 10' A.F.F., SMOOTH CONSTRUCTION UNLESS NOTED OTHERWISE.
 - MINIMUM CONDUIT SIZE SHALL BE 3/4"
 - ALL EXPOSED CONDUITS SHALL BE GRC (GALVANIZED RIGID METALLIC CONDUIT). ALL CONCEALED CONDUITS SHALL BE EMT (ELECTRICAL METALLIC TUBING). ALL UNDERGROUND CONDUIT SHALL BE PVC SCHEDULE 40 UNLESS NOTED.
 - MINIMUM CIRCUIT PERFORMANCE REQUIREMENTS:
 - IDC - INITIATING DEVICE CIRCUIT SHALL BE CLASS A
 - NAC - NOTIFICATION APPLICATION CIRCUIT SHALL BE CLASS A
 - SLC - SIGNALING LINE CIRCUIT SHALL BE CLASS A
 - ALL LOOPS SHALL HAVE OUTGOING AND RETURN CONDUCTORS IN SEPARATE CONDUIT.
 - CLASS A CIRCUITS SHALL BE INSTALLED SUCH THAT THE OUTGOING AND RETURN CONDUCTORS ARE SEPARATED 1 FOOT WHERE THE CABLE IS INSTALLED VERTICALLY AND 4 FEET WHERE THE CABLE IS INSTALLED HORIZONTALLY. THE OUT GOING AND RETURN CIRCUIT CONDUCTORS ARE PERMITTED TO BE INSTALLED IN THE SAME CONDUIT FOR A MAXIMUM DISTANCE OF 10 FEET WHERE THE OUTGOING AND RETURN CONDUCTORS ENTER OR EXIT THE DEVICE.
 - "T" TAPPING OF ANY CLASS "A" CIRCUIT IS PROHIBITED.
 - "ALLOW 3FT. OF CONDUCTOR LENGTH BETWEEN THE 120VAC SURGE SUPPRESSOR AND THE PROTECTED EQUIPMENT. THIS WILL ALLOW THE UNIT TIME TO REACT".



KEY PLAN
SCALE: NTS

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

PROJECT:

DRAWING TITLE:
FIRE ALARM SYSTEM
THIRD FLOOR PLAN

SCALE:
AS SHOWN


PROJECT NUMBER:

DATE:
09/23/2025

RE-WORK:
--

SHEET:
04 OF 9 SHEETS

FA-04



THIRD FLOOR

SECOND FLOOR

FIRST FLOOR


THIRD FLOOR

SECOND FLOOR

FIRST FLOOR

TAG	DESCRIPTION	TYPE	GAUGE	FPL	FPLR	FPLP	THHN	TFFN
A	ADDRESSABLE CIRCUIT (SLC)	UTP SOLID	18 AWG	X	X	X		
B	NOTIFICATION DEVICES (NAC)	2 COND. SOLID	14 AWG	X	X	X	X	X
C	DOOR HOLDER	2 COND. SOLID	14 AWG	X	X	X	X	X
D	ANNUNCIATOR BUS PRIMARY	2 COND. SOLID	18 AWG	X	X	X		
E	LOC BUS CONNECTION	2 COND. SOLID	18 AWG	X	X	X		
F	EXTERNAL AUDIO RISER	2 COND. SOLID	14 AWG	X	X	X	X	X
G	REMOTE TEST STATION	2 COND. SOLID	14 AWG	X	X	X		
H	AUX / POWER (24VDC)	2 COND. SOLID	14 AWG	X	X	X	X	X
I	AUDIO - SPEAKER	STP SOLID	18 AWG	X	X	X		
J	TRIGGER CIRCUIT	2 COND. SOLID	14 AWG	X	X	X	X	X


NOTE:
ALL CABLES ARE FOR INDOOR INSTALLATIONS. UNDERGROUND CABLE / WIRE MUST BE LISTED FOR INSTALLATION IN WET CONDITION.



PANEL TO PANEL CONNECTION DETAIL

FIRE ALARM RISER DIAGRAM
SCALE: NOT TO SCALE

- RISER NOTES:**
- RISER IS A DIAGRAMMATICAL REPRESENTATION OF THE SYSTEM ARCHITECTURE IN BUILDING CROSS SECTION. IT IS NOT INTENDED TO REPRESENT ACTUAL WIRE RUNS, PANEL CONFIGURATIONS OR PENETRATIONS. REFER TO FLOOR PLANS AND PANEL DETAILS FOR CIRCUIT ROUTING AND CONFIGURATION INFORMATION.
 - ALL WIRING SHALL COMPLY WITH APPLICABLE ELECTRICAL CODES. REFER TO 'APPLICABLE CODES & STANDARDS' ON SHEET FA-01 FOR SPECIFIC CODE REFERENCES.



John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

PROJECT:

DRAWING TITLE:

FIRE ALARM SYSTEM
RISER DIAGRAM &
PANEL TO PANEL
CONNECTION ARC.

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025

RE-WORK:

SHEET:

05 OF 9 SHEETS

FA-05

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HALL
STREET HILO, HI 96720

FIRE-ALARM by Honeywell		ES-1000X Battery Calculation									
Secondary Power Source Requirements											
Device Type		Standby Current (amps)				Secondary Alarm Current (amps)					
	Qty	x	Current Draw	=	Total		Qty	x	Current Draw	=	Total
Main Circuit Board	1	x	0.238000	=	0.238000		1	x	0.123000	=	0.123000
IPOTS-COM Communicator	1	x	0.040000	=	0.040000		1	x	0.041000	=	0.04100
PWRMOD24	1	x	0.007000	=	0.007000		1	x	0.008000	=	0.008000
ANN-BUS Devices											
ANN-80(-W)	1	x	0.015000	=	0.015000		1	x	0.040000	=	0.040000
Addressable Devices											
SD365R	2	x	0.000200	=	0.000400						
SD365	118	x	0.000200	=	0.023600						
H365	2	x	0.000200	=	0.000400						
D365PL	2	x	0.000200	=	0.000400						
MMF-300	1	x	0.000350	=	0.000350						
BG-12LX	15	x	0.000375	=	0.005625						
CRF-300	7	x	0.000270	=	0.001890						
Auxiliary Power											
RTS151KEY	2	x	0.012000	=	0.024000		2	x	0.012000	=	0.024000
Output Circuits											
NAC/Output #1			0.000000	=					0.607000	=	0.607000
NAC/Output #2			0.000000	=					1.186000	=	1.186000
NAC/Output #3			0.000000	=					1.520000	=	1.520000
BPS TRIGGER			0.000000	=					0.002000	=	0.002000
Total Standby Load					0.356665	Total Alarm Load					3.951000

EVAC ECC 50/100 BATTERY CALCULATION

<

dB Loss Calculations																				
DESCRIPTION	SPK			APPLIANCES QUANTITIES							TOTAL	ESTIMATED		MAXIMUM	TOTAL	ACTUAL	TOTAL			
	CIRCUIT	AMPLIFIER	WIRE	CIRCUIT	SPEAKER WATTAGE							CIRCUIT	CIRCUIT	ACTUAL	ALLOWABLE	CIRCUIT	VOLTAGE	VOLTAGE		
	NUMBER	NUMBER	GAUGE	VOLT	0.25W	0.5W	1W	2W	4W	8W	15W	(Watts)	(FEET)	LOSS	(dB)	CT. LENGTH	RESISTANCE	AT END	LOSS	LOSS
1ST FLOOR	S1	1	18 AWG	70 V	3	9						5.25 W	350 ft	-0.05 dB		300 ft	5.46 Ω	69.59	0.41	0.58%
1ST FLOOR	S2		18 AWG	70 V	10	2						3.50 W	330 ft	-0.03 dB		300 ft	5.15 Ω	69.74	0.26	0.37%
1ST FLOOR	S3		18 AWG	70 V	12	2						4.00 W	400 ft	-0.04 dB		32,543 ft	6.24 Ω	69.65	0.35	0.51%
2ND FLOOR	S4		18 AWG	70 V	26	10						11.50 W	950 ft	-0.30 dB		11,319 ft	14.82 Ω	67.65	2.35	3.36%
3RD FLOOR	S5		18 AWG	70 V	25	7						9.75 W	850 ft	-0.23 dB		13,351 ft	13.26 Ω	68.20	1.80	2.57%
		TOTAL CAPACITY			Appliance Summary							Total Load	SPARE CAPACITY	SPARE CAPACITY %						
		50W			76	30	0	0	0	0	0	34.00 W	16.00 W	32.00 %						

Enter current in amps.				Distance	Voltage		
150 = 150 mA				from previous device	At Device	Drop from source	Percent Drop
Device Number	Part Number	Device Candela	Device Current				
Panel	ES-1000X	NA	0.000	0	20.40	0.00	0.00%
FAN1-01	SPSWLED	15	0.018	32	20.28	0.118	0.58%
FAN1-02	SPSWLED	15	0.018	37	20.15	0.253	1.24%
FAN1-03	SPSWLED	15	0.018	18	20.08	0.317	1.55%
FAN1-04	SPSCWLED	177	0.115	41	19.94	0.456	2.24%
FAN1-05	SPSCWLED	177	0.115	18	19.90	0.504	2.47%
FAN1-06	SPSCWLED	177	0.115	18	19.86	0.539	2.64%
FAN1-07	SPSCWLED	75	0.070	22	19.83	0.567	2.78%
FAN1-08	SCWLED	15	0.018	27	19.81	0.590	2.89%
FAN1-09	SCWLED	15	0.018	12	19.80	0.599	2.94%
FAN1-10	SPSCWLED	15	0.018	15	19.79	0.608	2.98%
FAN1-11	SPSCWLED	15	0.018	11	19.77	0.614	3.01%
FAN1-12	SPSCWLED	30	0.022	35	19.77	0.628	3.08%
FAN1-13	SPSCWLED	30	0.022	29	19.76	0.636	3.12%
FAN1-14	SPSCWLED	30	0.022	19	19.76	0.638	3.13%
END				20	19.76	0.638	3.13%
Totals			0.607	354	End of Line Voltage		19.76

Notification Power Supply FL-PS10						
Battery Calculation						
COMPONENT	QTY.	Standby (A)	Alarm (A)	Standby Total	Alarm Total	
Main Circuit Board	1	0.178	0.232	0.178	0.232	
ZNAC-PS	1	0.149	0.159	0.149	0.159	
1.N1	1	0.000	1.544	0.000	1.544	
1.N2	1	0.000	1.686	0.000	1.686	
1.N3	1	0.000	1.923	0.000	1.923	
1.N4	1	0.000	1.190	0.000	1.190	
DOOR HOLDER	4	0.020	0.000	0.080	0.000	
Totals				0.407	6.734	
Battery Calculation	Hrs	Current	AH	Safety	Batt Req (AH)	
Door holder (Dropout in AC loss)	0.0830	0.080	0.007			
Normal	24	0.327	7.848			
Alarm 15 min.	0.25	6.734	1.684			
Total Required			9.532	1.250	11.914	
* Battery Supplied	2 ea 12V				12 AH	
* 24VDC System Requires Two 12VDC Batteries						

NOTE: Class A supervision and the ZNAC-PS module are not intended for use with door holder operation.

BATTERY CALCULATION FOR HWF2V-COM COMMUNICATOR							
Device or Control		Standby Current in mA			Alarm Current (mA)		
		QTY	Current	Total	QTY.	Current	Total
HONEYWELL	HWF2V-COM	1	210	210	1	290	290
Standby Total: (mA)				210.00	Total Alarm (mA)		290
Standby:		210.00	mA X	24	Hrs =	5.04	A
Alarm:		290	mA X	0.083	Hrs =	0.02407	A
Sub Total:						5.06407	A
Surplus:		25%				1.01281	A
Total Requirement:						6.08	Ah
Battery Required:		ONE (1) 7 AH batteries					

Circuit Number	FA.N2						
Nominal System Voltage	20.4						
Minimum Device Voltage	16						
Total Circuit Current	1.186						
Wire Gauge for balance of circuit	Wire Gauge Ohm/Per 1000 14 3.07						
Enter current in amps. 150 = 150 ma				Distance from previous device	Voltage		
Device Number	Part Number	Device Candela	Device Current		At Device	Drop from source	Percent Drop
Panel	ES-100X	NA	0.000	0	20.40	0.000	0.00%
FAN2-01	SPSCWLED	15	0.018	51	20.03	0.372	1.82%
FAN2-02	SPSCWLED	177	0.115	17	19.91	0.492	2.41%
FAN2-03	SPSCWLED	177	0.115	28	19.73	0.675	3.31%
FAN2-04	SPSCWLED	177	0.115	19	19.62	0.782	3.83%
FAN2-05	SPSCWLED	177	0.115	29	19.47	0.929	4.55%
FAN2-06	SPSCWLED	177	0.115	18	19.39	1.009	4.95%
FAN2-07	SPSCWLED	15	0.018	19	19.32	1.078	5.29%
FAN2-08	SPSCWLED	177	0.115	19	19.26	1.145	5.61%
FAN2-09	SPSCWLED	177	0.115	18	19.20	1.197	5.87%
FAN2-10	SPSCWLED	177	0.115	29	19.14	1.259	6.17%
FAN2-11	SPSCWLED	177	0.115	19	19.12	1.285	6.30%
FAN2-12	SPSCWLED	177	0.115	28	19.10	1.305	6.40%
END				40	19.10	1.305	6.40%
Totals			1.186	335	End of Line Voltage		19.10

Circuit Number	1.N1					
Nominal System Voltage	20.4					
Minimum Device Voltage	16					
Total Circuit Current	1.544					
Wire Gauge for balance of circuit	14					
Enter current in amps.					Ohm's Per 1000	
.150 = 150 ma					3.07	
Device Number	Part Number	Device Candela	Device Current	Distance from previous device	Voltage Drop from source	Percent Drop
Panel	FL-PS10	NA	0.000	0	20.40	0.00%
1.N1-01	SPSCWLED	15	0.018	50	19.93	0.47%
1.N1-02	SPSCWLED	30	0.022	23	19.71	0.69%
1.N1-03	SCWLED	15	0.018	31	19.42	0.97%
1.N1-04	SCWLED	15	0.018	10	19.33	1.06%
1.N1-05	SPSCWLED	15	0.018	11	19.24	1.16%
1.N1-06	SPSCWLED	177	0.115	33	18.95	1.45%
1.N1-07	SPSCWLED	177	0.115	19	18.79	1.61%
1.N1-08	SPSCWLED	177	0.115	23	18.62	1.78%
1.N1-09	SPSCWLED	177	0.115	19	18.42	1.98%
1.N1-10	SPSCWLED	177	0.115	19	18.30	2.09%
1.N1-11	SPSCWLED	177	0.115	19	18.15	2.25%
1.N1-12	SPSCWLED	177	0.115	18	18.06	2.37%
1.N1-13	SPSCWLED	75	0.070	16	18.00	2.40%
1.N1-14	SPSCWLED	177	0.115	15	17.94	2.45%
1.N1-15	SPSCWLED	177	0.115	19	17.89	2.50%
1.N1-16	SPSCWLED	177	0.115	29	17.83	2.57%
1.N1-17	SPSCWLED	177	0.115	19	17.80	2.59%
1.N1-18	SPSCWLED	177	0.115	29	17.78	2.61%
RETURN				90	17.78	2.61%
Totals			1.544	512	End of Line Voltage	17.78

Circuit Number				1.N2			
Nominal System Voltage					20.4		
Minimum Device Voltage					16		
Total Circuit Current				1.686	Wire Gauge	Ohm's Per 1000	
Wire Gauge for balance of circuit					14	3.07	
Enter current in amps. .150 = 150 ma.				Distance from previous device	Voltage Drop from source		
Device Number	Part Number	Device Cavels	Device Current		At Device	Percent Drop	
Panel	FL-PS10	NA	0.000	0	20.40	0.000	0.00%
1.N2-01	SPSCWLED	177	0.115	67	19.71	0.694	3.40%
1.N2-02	SPSCWLED	177	0.115	18	19.53	0.871	4.27%
1.N2-03	SPSCWLED	177	0.115	29	19.27	1.127	5.52%
1.N2-04	SPSCWLED	177	0.115	18	19.12	1.277	6.26%
1.N2-05	SPSCWLED	177	0.115	29	18.90	1.497	7.34%
1.N2-06	SPSCWLED	177	0.115	19	18.77	1.625	7.97%
1.N2-07	SPSCWLED	15	0.018	19	18.66	1.739	8.53%
1.N2-08	SPSCWLED	177	0.115	19	18.55	1.852	9.08%
1.N2-09	SPSCWLED	177	0.115	19	18.45	1.952	9.57%
1.N2-10	SPSCWLED	177	0.115	28	18.32	2.083	10.21%
1.N2-11	SPSCWLED	177	0.115	19	18.24	2.157	10.57%
1.N2-12	SPSCWLED	30	0.022	27	18.16	2.242	10.99%
1.N2-13	SPSCWLED	177	0.115	25	18.08	2.320	11.37%
1.N2-14	SPSCWLED	177	0.115	25	18.02	2.379	11.66%
1.N2-15	SPSWLED	15	0.018	33	17.97	2.432	11.92%
1.N2-16	SPSWLED	15	0.018	34	17.92	2.484	12.18%
1.N2-17	SPSCWLED	177	0.115	22	17.89	2.515	12.33%
1.N2-18	SPSCWLED	177	0.115	22	17.87	2.530	12.40%
RETURN				70	17.87	2.530	12.40%
Totals				542	End of Line Voltage	17.87	

Circuit Number	1.N4					
Nominal System Voltage	20.4					
Minimum Device Voltage	16					
Total Circuit Current	1.190					
Wire Gauge for balance of circuit	Wire Gauge 14 Ohm's Per 1000 3.07					
Enter current in amps. .150 = 150 ma				Distance from previous device	Voltage Drop from source	Percent Drop
Device Number	Part Number	Device Candela	Device Current			
Panel	FL-PS10	NA	0.000	0	20.40	0.00%
1.N4-01	SPSCWLED	177	0.115	14	20.30	0.102 0.50%
1.N4-02	SPSCWLED	177	0.115	29	20.11	0.232 1.43%
1.N4-03	SPSCWLED	177	0.115	18	20.00	0.399 1.96%
1.N4-04	SPSCWLED	177	0.115	29	19.85	0.551 2.70%
1.N4-05	SPSCWLED	177	0.115	19	19.67	0.635 3.11%
1.N4-06	SPSCWLED	15	0.018	19	19.69	0.705 3.46%
1.N4-07	SPSCWLED	177	0.115	19	19.63	0.774 3.80%
1.N4-08	SPSCWLED	177	0.115	18	19.57	0.829 4.06%
1.N4-09	SPSCWLED	177	0.115	29	19.51	0.895 4.39%
1.N4-10	SPSCWLED	177	0.115	19	19.48	0.923 4.53%
1.N4-11	SPSCWLED	30	0.022	27	19.45	0.946 4.64%
1.N4-12	SPSCWLED	177	0.115	24	19.44	0.963 4.72%
RETURN				40	19.44	0.963 4.72%
Totals			1.190	304	End of Line Voltage	19.44

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

DRAWING TITLE

FIRE ALARM SYSTEM CALCULATIONS

SCALE:

AS SHOWN

PROJECT NUMBER

DATE:

09/23/2025

RE-WORK:

— —


SHEET:

06 OF 9 SHEETS


FA-06

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025


ELECTRICAL CONTRACTOR:
Z,S ELECTRICAL 122 HAILI
STREET HILO, HI 96720




ES-1000X CABINET MOUNTING



ECC-50/100 WIRING DETAILS



ES-1000X WIRING



FL-PS10 WIRING

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

PROJECT:

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HAILI
STREET HILO, HI 96720

DRAWING TITLE:

FIRE ALARM SYSTEM
WIRING DETAIL

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025


RE-WORK:

--


SHEET:

07 OF 9 SHEETS


FA-07



HWF2V-COM WIRING DETAIL



ECC-50/100 & ECC-LOC WIRING DETAIL



FM-998 WIRING DETAIL

John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

PROJECT:

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HAILI
STREET HILO, HI 96720

DRAWING TITLE:

FIRE ALARM SYSTEM
WIRING DETAIL

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025









RE-WORK:

--

SHEET:

08 OF 9 SHEETS

FA-08



John Mocker, SET
John Mocker
NICET Level IV - Fire Alarm
Technician ID: 137219
Expires: 11/1/2025

MEDCOM BUILDING 46
91-1227 ENTERPRISE AVENUE
KAPOLEI, HI 96707

PROJECT:

ELECTRICAL CONTRACTOR:
Z/S ELECTRICAL 122 HAILI
STREET HILO, HI 96720

DRAWING TITLE:

FIRE ALARM SYSTEM
WIRING DETAIL

SCALE:

AS SHOWN

PROJECT NUMBER:

DATE:

09/23/2025

RE-WORK:

--

SHEET:

09 OF 9 SHEETS

FA-09

CA-202505-C Addendum

Attachment #3

BLDG 46 Specification Section 08111

SECTION 08111 – HOLLOW METAL DOORS AND FRAMES

PART 1 - GENERAL

1.01 SUMMARY:

A. Section Includes:

1. Exterior hollow-metal doors and frames.
2. Hollow-metal panels where indicated.

B. Related Requirements:

1. Division 01 – General Requirements: Administrative, procedural, and temporary work requirements.
2. SECTION 08710 – FINISH HARDWARE
3. SECTION 08800 – GLAZING
4. SECTION 09901 – PAINTING

1.02 REFERENCES

A. ASTM International (ASTM)

1. ASTM A153/A153M – Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware
2. ASTM A653/A653M – Standard Specification for Steel Sheet, Zinc-Coated or Zinc-Iron Alloy-Coated by the Hot-Dip Process.
3. ASTM A879/A879M – Standard Specification for Steel Sheet, Zinc Coated by the Electrolytic Process for Applications Requiring Designation of the Coating Mass on Each Surface.
4. ASTM A1008/A1008M – Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable.
5. ASTM A1011/A1011M – Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength.

B. Steel Door Institute (SDI)

1. SDI A250.4 – Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames, Frame Anchors and Hardware Reinforcings
2. SDI A250.6 – Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames
3. SDI A250.8 – Specifications for Standard Steel Doors and Frames
4. SDI A250.10 – Test Procedure and Acceptance Criteria for Prime Painted Steel

Surfaces for Steel Doors and Frames

5. SDI A250.11 – Recommended Erection Instructions for Steel Frames

1.03 SUBMITTALS

- A. Submit in accordance with SECTION 01300 – SUBMITTAL PROCEDURES.
- B. Pre-Construction Submittals:
 - 1. Product Data: Manufacturer's descriptive data for each type of door, frame, core, accessory, and finish.
 - 2. Shop Drawings: Indicate elevations, dimensions, profiles, metal thicknesses, hardware preparations and reinforcements, anchors, joints, field splices, glazing, accessories, and adjacent construction.
 - 3. Door and Frame Schedule: Use the same opening references indicated on the Drawings and coordinate with the final Door Hardware Schedule.
- C. Informational Submittals:
 - 1. Product Test Reports: For each type of hollow-metal door and frame assembly, prepared by a qualified testing agency.
 - 2. Oversize Construction Certification: For fire-rated assemblies exceeding the size limitations of labeled assemblies, where applicable.

1.04 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer specializing in hollow-metal doors and frames with a minimum five years documented experience.
- B. Installer Qualifications: Minimum five years experience in work of this Section.

1.05 DELIVERY, STORAGE AND HANDLING

- A. Deliver hollow-metal work palletized, packaged, or crated to protect against damage during transit and storage. Do not use nonvented plastic
- B. Deliver welded frames with two removable spreader bars tack welded to jambs at the bottom of frames
- C. Store hollow-metal work vertically under cover, with heads up, on minimum 4-inch-high wood blocking.
- D. Provide minimum 1/4-inch space between stacked doors to permit air circulation. Protect factory-finished units from damage

PART 2 – PRODUCTS

2.01 MANUFACTURERS

- A. Provide products by a qualified hollow-metal manufacturer regularly engaged in manufacturing doors and frames complying with this Section

- B. Substitutions: In accordance with Division 01 requirements.

2.02 EXTERIOR HOLLOW-METAL DOORS AND FRAMES

- A. Extra-Heavy-Duty Doors and Frames: SDI A250.8, Level 3.

1. Physical Performance: Level A in accordance with SDI A250.4.
 2. Doors:
 - a. Type: As indicated in the Door and Frame Schedule
 - b. Thickness: 1-3/4 inches.
 - c. Face: Metallic-coated steel sheet, minimum 0.053-inch thickness, with minimum A60 coating
 - d. Edge Construction: Model 2, seamless.
 - e. Core: Manufacturer's standard kraft-paper honeycomb, polystyrene, polyurethane, polyisocyanurate, mineral-board, or vertical steel-stiffener core.
 3. Frames:
 - a. Material: Metallic-coated steel sheet, minimum 0.053-inch thickness, with minimum A60 coating.
 - b. Construction: Full-profile welded.
 4. Exposed Finish: Prime.
- B. Hollow-Metal Panels: Provide panels of the same materials, construction, and finish as adjacent door assemblies.

2.03 FRAME ANCHORS

- A. Jamb Anchors:
 1. Stud-Wall Type: Designed to engage studs, welded to backs of frames, and not less than 0.042 inch thick.
- B. Floor Anchors: Formed from the same material as frames, minimum 0.042 inch thick, with two holes for fasteners at monolithic concrete slabs

2.04 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A1008/A1008M, Commercial Steel, Type B, suitable for exposed applications.
- B. Hot-Rolled Steel Sheet: ASTM A1011/A1011M, Commercial Steel, Type B, free of scale, pitting, and surface defects; pickled and oiled.
- C. Metallic-Coated Steel Sheet: ASTM A653/A653M, Commercial Steel, Type B.
- D. Frame Anchors: ASTM A879/A879M, Commercial Steel, 12G coating designation, mill

phosphatized. Hot-dip galvanize anchors built into exterior walls in accordance with ASTM A153/A153M, Class B.

- E. Inserts, Bolts, and Fasteners: Hot-dip galvanized in accordance with ASTM A153/A153M.
- F. Power-Actuated Fasteners in Concrete: Corrosion-resistant fastener system suitable for the application indicated.
- G. Mineral-Fiber Insulation: ASTM C665, Type I, unfaced slag- or rock-wool fiber with maximum flame-spread index of 25 and smoke-developed index of 50.

2.05 FABRICATION

- A. Fabricate hollow-metal work rigid, free of defects, warp, and buckle, and accurately formed to required sizes and profiles. Factory fit and assemble units where practical.
- B. Close door top edges with flush closures of the same material as face sheets. Provide bottom closures or channels where required for weather stripping.
- C. Provide weep-hole openings at bottoms of exterior doors and seal joints in top edges against water penetration.
- D. Fabricate frames in sections only where required by shipping or handling limitations; provide alignment plates or angles at joints of the same metal thickness as frames.
- E. Weld floor anchors to jamb bottoms with at least four spot welds per anchor, except provide anchor clips or countersunk holes for slip-on drywall frames.
- F. Provide jamb anchors in number and spacing required by SDI A250.8 and the wall construction indicated.
- G. Provide three silencers at strike jambs of single-door frames and two silencers at heads of double-door frames, except at weather-stripped frames.
- H. Factory prepare doors and frames for hardware in accordance with SDI A250.6, BHMA A156.115, the Door Hardware Schedule, and approved templates.

2.06 STEEL FINISHES

- A. Prime Finish: Clean, pretreat, and apply manufacturer's standard primer.
 - 1. Shop Primer: Fast-curing, lead- and chromate-free primer complying with SDI A250.10 and compatible with specified field-applied coatings.

PART 3 – EXECUTION

3.01 EXAMINATION

- A. Examine substrates, openings, and conditions for compliance with installation tolerances and conditions affecting performance.
- B. Verify locations of embedded and built-in anchors before frame installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Remove welded-in shipping spreaders. Grind, fill, and dress exposed surfaces so repaired areas are smooth, flush, and invisible.
- B. Drill and tap doors and frames for nontemplated mortised and surface-mounted hardware.

3.03 INSTALLATION

- A. Install hollow-metal work plumb, rigid, properly aligned, and securely fastened in accordance with the Drawings and manufacturer's instructions
- B. Install hollow-metal frames in accordance with SDI A250.11.
 - 1. Set frames accurately in position; plumb, align, and brace securely until permanent anchors are set.
 - 2. Field splice sectional frames at approved locations by continuously welding face joints; grind, fill, and dress splices smooth, flush, and invisible.
 - 3. Provide floor anchors at each jamb and mullion extending to the floor and secure with postinstalled expansion anchors.
 - 4. Solidly pack mineral-fiber insulation inside frames installed in metal-stud partitions.
 - 5. Installation Tolerances:
 - a. Squareness: Plus or minus 1/16 inch.
 - b. Alignment: Plus or minus 1/16 inch.
 - c. Twist: Plus or minus 1/16 inch.
 - d. Plumbness: Plus or minus 1/16 inch.
- C. Fit hollow-metal doors accurately within frames.
 - 1. Clearances:
 - a. Between door and frame jambs and head: 1/8 inch, plus or minus 1/32 inch
 - b. Between edges of pairs of doors: 1/8 inch to 1/4 inch, plus or minus 1/32 inch.
 - c. At bottom of door: 5/8 inch, plus or minus 1/32 inch.
 - d. Between door face and stop: 1/16 inch to 1/8 inch, plus or minus 1/32 inch.

3.04 ADJUSTING AND CLEANING

- A. Check and readjust operating hardware immediately before final inspection. Leave work in complete and proper operating condition.
- B. Remove and replace defective, warped, bowed, or otherwise unacceptable hollow-metal work.

- C. Remove grout, adhesive, and other foreign matter immediately after installation.
- D. Sand rusted or damaged prime-coated areas smooth and apply compatible rust-inhibitive touchup primer.
- E. Repair abraded metallic-coated surfaces with galvanizing repair paint in accordance with manufacturer's instructions.

3.05 PROTECTION

- A. Protect installed hollow-metal work from damage until completion of construction.

END OF SECTION 08111