

STATEMENT OF WORK

FOR

MAINTENANCE

OF

**LOW OBSERVERABLE/COMPOSITE
REPAIR FACILITY (LO/CRF)**

**JOINT BASE PEARL HARBOR-HICKAM,
OAHU, HAWAII**

JULY 2016

PART I: SUPPLIES OR SERVICES AND PRICES/COSTS

TABLE OF CONTENTS.....2-3

SCHEDULE OF SERVICES..... 3-19

A. 0001-LO PAINT BOOTH INSERTS.....4-5

B. 0002-LO PAINT BOOTH AIR CHILLER SYSTEMS 5

C. 0003-AIR COMPRESSOR/AIR DRYERS/BREATHING
AIR COMPRESSORS 6-7

D. 0004-LO PAINT BOOTH AIR MAKE-UP UNITS/
EXHAUST UNITS 8

E. 0005-LO PLASTIC MEDIA BLASTER CABINET 9

F. 0006-LO PAINT BOOTH FACILITY DOORS.....10

G. 0007-LO PAINT BOOTH/FILTRATION SYSTEM..... 11

H. 0008-LO/COMPOSITE SANDING BOOTH 12

I. 0009-STRUCTURAL SHOP 12

J. 0010-PREP ROOM 13

K. 0011-TOOL ROOM CORRIDOR 13

L. 0012-CURE ROOM.....14

M. 0013-MATERIAL ROOM.....14

N. 0014-MECHANICAL ROOM.....15

O. 0015-OUTSIDE MECHANICAL ROOM NEXT TO
BUILDING.....16

P. 0016-BAY 1.....17

Q. 0017-BAY 2 18

PART II SCOPE OF SERVICES

**II. DESCRIPTION FOR LO PAINT BOOTH EQUIPMENT
AND ACCESSORIES**

A.1 GENERAL INTENTION	20
A.2 GENERAL REQUIREMENTS.....	20
A.3 DEFINITIONS – TECHNICAL	21
A.4 GOVERNMENT FURNISHED PROPERTY AND SERVICES	21-22
A.5 CONTRACTOR FURNISHED ITEMS	22
A.6 MANAGEMENT	22-23
A.7 GENERAL REQUIREMENTS AND PROCEDURES..	23
A.8 STATION REGULATIONS.....	24
A.9 ENVIRONMENTAL PROTECTION.....	24
A.10 SAFETY REQUIREMENTS AND REPORTS.....	24
A.11 SECURITY REQUIREMENTS AND REPORTS.....	24
A.12 PERMITS.....	24
A.13 INSURANCE.....	24-25

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
--	--	-----------------------	-------	---------------	--------

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

0001	<p>FIRM FIXED-PRICE WORK:</p> <p>LO Paint Booth Inserts:</p> <ul style="list-style-type: none"> a. Check, repair, and replace all mechanical and moving parts, to include but is not limited to, doors and hinges as required. b. Check and repair or replace all electrical components, wiring and parts as required. c. Inspect structure and repair or replace any loose or damaged items as required. d. Check and repair or replace all compressed air lines and/or water separator /regulator as required. e. Inspect and clean the walls, ceiling, ductwork and light covers as required. f. Clean and repair or replace all ductwork as required. g. Replace bulbs, ballasts, seals and glass fixtures as required. h. Repair or replace all electrical components, wiring and parts as required. i. Booths 1 and 2 are expected to be operational 95% of the year including weekends and federal holidays. Booth down time shall not exceed one and one half day per month. j. Booths 1 and 2 are expected to maintain a temperature range from 70-85 degrees and 40 to 60 percent humidity level during operational periods. k. All maintenance shall be performed in accordance with manufactures' recommendations. 	Monthly	Lump Sum	\$	\$
	<p>TOTAL PRICE FOR CONTRACT LINE ITEM 0001</p>				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0002	FIRM FIXED-PRICE WORK: LO Paint Booth Air Chiller Systems: <ul style="list-style-type: none"> a. Inspect system to ensure it is functioning properly. b. Check and replace any malfunctioning parts as required. c. Check, repair or replace any electrical parts as required. d. Check and repair or replace any and all airlines as required. e. Lubricate any and all moving parts as required. f. All maintenance shall be performed in accordance with manufactures' recommendations. 	Monthly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0002				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0003	<p>FIRM FIXED-PRICE WORK: Air Compressor/Air Dryers/Breathing Air Compressors:</p> <ul style="list-style-type: none"> a. Check and ensure all mechanical parts are in proper working order. b. Check and repair all electrical components as required. c. Check and refill all refrigerant level as required. d. Clean and or replace all filters as required. e. Inspect, adjust and replace belts as required. f. Repair leaks and replace parts to ensure proper operation as required. g. Clean after cooler and lubricate cooler fins. h. Lubricate motors and bearings as necessary. i. Make all required service adjustments to the pilot valves, pressure switches and regulating valves. j. Perform regular oil changes and dispose of all used and unused oil at an off base location in accordance with applicable federal, state, and local pollution laws and regulations. (every six months). k. Take quarterly breathing air samples on oiled breathing air compressors and have tested for contaminants. Results must be provided to QAP each quarter. (quarterly). 	Monthly (Unless otherwise indicated in Red)	Lump Sum	\$	\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0003	<p>Air Compressor/Air Dryers/Breathing Air Compressors:</p> <ul style="list-style-type: none"> l. Contractor shall ensure all breathing air equipment is manufacturer specific from the air pressure regulator to the breathing apparatus, to include breathing air hose. Must comply with OSHA standards. m. Ensure all periodic and preventative maintenance is completed on schedule as per manufacturers' recommendations. n. All maintenance shall be performed in accordance with manufacturers' recommendations. 	Monthly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0003				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0004	<p>FIRM FIXED-PRICE WORK: LO Paint Booth Air Make-up Units/Exhaust Units:</p> <ul style="list-style-type: none"> a. Check and ensure all parts are in correct working order. b. Check and repair or replace all electrical components, wiring and parts not limited to but to include fuses as required. c. Inspect, adjust all replace as required all belts. d. Clean, repair or replace fan blades and all ductwork as required. e. Repair or replace all loose or bad bearings. f. Make adjustments and alignments to all pulleys and sheaves. g. Lubricate motors as required. h. Clean and repair evaporative cooling system or as required by 5.g i. Repair leaks and replace parts to ensure proper operation as required. j. All maintenance shall be performed in accordance with manufactures' recommendations. 	Monthly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0004				\$

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0005	<p>FIRM FIXED-PRICE WORK:</p> <p>LO Plastic Media Blaster Cabinet:</p> <ul style="list-style-type: none"> a. Check and ensure all moving parts are in working order. b. Replace bulbs, ballasts, seals and glass when required. c. Check and repair or replace all mechanical and pneumatic components as required. d. Repair or replace all electrical components, wiring and parts as required. e. Check, clean or replace all filters as required. f. Repair leaks and replace parts as needed for proper operation. g. All maintenance shall be performed in accordance with manufactures' recommendations. 	Quarterly	Lump Sum	\$	\$
0005	TOTAL PRICE FOR CONTRACT LINE ITEM 0005				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0006	FIRM FIXED-PRICE WORK: LO Paint Booth Facility Doors: a. Lubricate all mechanical parts as required. b. Repair or replace all electrical and mechanical parts such as but is not confined to sensors, switches, latches, motors and hinges as required. c. Replace all door seals as needed. d. All maintenance shall be performed in accordance with manufactures' recommendations.	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0006				\$

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
--	--	-----------------------	-------	---------------	--------

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

0007	<p>FIRM FIXED-PRICE WORK:</p> <p>LO Paint Booth/Filtration Systems:</p> <ul style="list-style-type: none"> a. Remove and replace all particulate filters as needed by manometer reading, ensuring 01 September 1998 National Emission Standards for Hazardous Air Pollutants (NESHAP) requirements are met. b. Remove, empty, refill and replace carbon banks charcoal filters. c. Contractor takes monthly samples from charcoal filtering banks and has tested to evaluate for charcoal filter efficiency, then forward copy of results to contract QAP. Contractor assumes responsibility and charges (costs) for all filter tests. d. All maintenance shall be performed in accordance with manufactures' recommendations. 	Monthly	Lump Sum	\$	\$
	<p>TOTAL PRICE FOR CONTRACT LINE ITEM 0007</p>				\$

SCHEDULE

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

		Estimated Quantity	Unit*	Unit Price	Amount
0008	FIRM FIXED-PRICE WORK: LO/Composite Sanding Booth: a. Check and lubricate all moving parts. b. Check and replace all filters as required. c. All maintenance shall be performed in accordance with manufactures' recommendations.	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0008				\$

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0009	FIRM FIXED-PRICE WORK: Structural Shop: a. Breathing Air Panels and Regulators (None) b. Compressed Air Regulators/Filters (16 each) c. Compressed Air Hose Reels with hoses (four each)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0009				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0010	FIRM FIXED-PRICE WORK: Prep Room: a. Breathing Air Panels and Regulators (six each) b. Compressed Air Regulators/Filters (18 each) c. Compressed Air Hose Reels with hoses (six each) 1) Sanding Booth – (one each) (Dual Draw) 2) Blast Cabinet – one each (Pauli Systems Ram 35) 3) LO Composite Shredder and Dust Collector	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0010				\$

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0011	FIRM FIXED-PRICE WORK: Tool Room Corridor: a. Compressed Air Regulators/Filters two each b. Breathing Air Regulators (none). c. Compressed Air Hose Reels with hoses (none)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0011				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0012	FIRM FIXED-PRICE WORK: Cure Room: a. Breathing Air Panels and Regulators – (six each) b. Compressed Air Regulators/Filters – (18 each) c. Compressed Air Hose Reels with hoses – (six each) 1) Composite Cure Oven – (one each) (Wisconsin)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0012				\$

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

0013	FIRM FIXED-PRICE WORK: Material Room: a. Breathing Air Panels and Regulators – (one each) b. Compressed Air Regulators/Filters – (none) c. Compressed Air Hose Reels with hoses – (none)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0013				\$

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

0014	FIRM FIXED-PRICE WORK: Mechanical Room: a. Breathing Air Panels and Regulators – (none) b. Compressed Air Regulators/Filters – (none). c. Compressed Air Hose Reels – (none) 1) Vacuum Pump – (one each) (PowerEx – Process vacuum system PV-1) 2) Breathing Air Compressor – (one each) (PowerEx) 3) Dominick Hunter Breathing Air Purifier 4) Tool Air Compressors – (two each) (Quincy Northwest) 5) Tool Air Dryer – (one each) (Zeks Heatsink Tru-Cycling Air Dryer) 6) Oil Water Separator – (one each)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0014				\$

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
0015	FIRM FIXED-PRICE WORK: Outside Mechanical Room Next to Building: a. Central Vacuum System – (one each) (Supports Bay – one & two) b. Central Vacuum Clean Separator – (one each) (Supports Bay – one & two) c. Dryer Cooler DC – 1 for Tool Air Compressors – (one each) (Supports Air Compressors)	Quarterly	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0015				\$

SCHEDULE

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

	TOTAL PRICE FOR CONTRACT LINE ITEM 0016				\$
--	--	--	--	--	----

SCHEDULE

		Estimated Quantity	Unit*	Unit Price	Amount
--	--	-----------------------	-------	---------------	--------

Maintenance of LO/ Composite Facility
 Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

0017	<p>FIRM FIXED-PRICE WORK:</p> <p>Bay 2:</p> <ul style="list-style-type: none"> a. Paint Booth Intake Plenum Motorized Filter Doors – (two each) (GPS) b. Fall Protection System – (three each) c. Breathing Air Panels and Regulators – (nine each) d. Compressed Air Regulators/Filters – (18 each) e. Compressed Air Hose Reels – (none) f. Explosion Proof Fluorescent Lights – (61 each) g. Intake Plenum Door Filters – (270 each) (24x24x2) (Separate Clin) LO Particulate Exhaust Filters <ul style="list-style-type: none"> 1) Stage 1 – (234 each) (24x24x2) (Replaced Quarterly) 2) Stage 2 – (234 each) (24x24x2) (Replaced Quarterly) 3) Stage 3 – (234 each) (24x24x20/5 pockets) (Replaced as needed) 4) VOC Carbon Filters – (60 each) (24x24x12) (Replaced as needed) h. Make-up Air Desiccant Dehumidification Wheel Dryers – (two each) (Semco) i. Trane Air Make-up Units with Chiller Coils – (two each) j. LEL Monitor with remote sensors – (one each) (Chemguard) 	Monthly (Unless otherwise indicated in Red)	Lump Sum	\$	\$
	TOTAL PRICE FOR CONTRACT LINE ITEM 0017				\$

- **NOTE: Line Items 0016 g) and 0017 g) are to be paid by Users funds and are to be listed as separate clin numbers**

END OF PART I

PART II – SCOPE OF SERVICES

SECTION A: DESCRIPTION FOR LO PAINT BOOTH EQUIPMENT AND ACCESSORIES

- A.1 GENERAL INTENTION. The intention of this solicitation is to obtain maintenance and repair services for the LO/Composite Repair Facility systems at the 154th Wing, Hawaii Air National Guard Facilities located on Hickam Air Force Base, Oahu, Hawaii by means of a firm fixed-price contract. The contract shall include research, troubleshoot, furnish all materials, labor, equipment and transportation necessary to service and perform preventative maintenance on the paint booth equipment and related accessories.
- a. Preventative Maintenance (PM): Preventative maintenance will be on a thirty (30) day interval (unless otherwise indicated) excluding federal holidays. Contractor shall provide the Contracting Officer (KO) and the Quality Assurance Person (QAP) a detailed monthly service report to provide historical record of PM services performed.
 - b. Emergency Repair: Emergency maintenance will be on an on-call basis with response time not to exceed Twelve (12) hours including federal holidays and weekends. All repair work shall be in accordance with commercial practices using parts specified by the equipment manufacturer or items of equal or better quality. Downtime of the equipment will be as prescribed in Section 1, Schedule of Services.
 - c. Replacement Parts and Equipment: The Contractor shall furnish all replacement parts/equipment in accordance with manufacturer specifications. The Contractor shall own all parts/equipment purchased until they are satisfactorily installed on government owned equipment or property. The Contractor shall bill for replacement parts/equipment as a separate item in accordance with the contract. The Contractor shall then be reimbursed by the Government at actual supplier invoice cost to the Contractor for all parts/equipment used. The contractor shall verify necessity of replacement parts/equipment through the QCP. Contractor shall also stock common replacement parts (ie. Recurring maintenance parts and sensors) locally, to minimize down time of essential equipment to facilitate LOCRF continued operations. Contractor shall be responsible to store hazardous/flammable material off site. The contractor shall exercise all options available for discounts and rebates so as to procure items meeting specifications herein at the most advantageous price possible. Discounts and rebates on item provided to the Contractor shall be credited to the Government.
- A.2 GENERAL REQUIREMENTS. The Contractor shall furnish all labor, supervision, tools, materials, equipment, transportation, and management necessary to provide testing and repair services for fire protection systems in accordance with the requirements specified herein. Work includes the maintenance of all systems in the LO/CRF, fixed quantity of work to make certain specific repairs, and other services as described herein.
- a. Appendix A describes the systems and equipment to be serviced under the contract, which include:
 - (1) LO Paint Booth Inserts
 - (2) LO Paint Booth Air Chiller Systems

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

- (3) Air Compressor/Air Dryer/Breathing Air Compressors
- (4) LO Paint Booth Air Make-up Units/Exhaust Units
- (5) LO Plastic Media Blaster Cabinet
- (6) LO Paint Booth Facility Doors
- (7) LO Paint Booth/Filtration Systems
- (8) LO/Composite Sanding Booth
- (9) Structural Shop
- (10) Prep Room
- (11) Tool Room Corridor
- (12) Cure Room
- (13) Material Room
- (14) Mechanical Room
- (15) Outside Mechanical Room Next to Building
- (16) Bay 1
- (17) Bay 2

A.3 DEFINITIONS - TECHNICAL. As used throughout this contract, the following terms shall have the meaning set forth below.

- a. Contracting Officer. The KO is a person with the authority to enter into, administer, and terminate contracts and make related determinations and findings. The term includes certain authorized representatives of the KO acting within the limits of their authority as delegated by the KO.
- b. Contractor. The term Contractor as used herein refers to both the prime Contractor and any subcontractors. The prime Contractor shall ensure that his/her subcontractors comply with the provisions of this contract.
- c. Damages. Any government or privately owned property damaged by the contractor shall be replaced or repaired immediately by the contractor at no expense to the government.
- d. Safety. The contractor shall comply with all applicable OSHA, Federal, State, local and Joint Base Pearl Harbor-Hickam safety regulations.
- e. Quality Control. The Contractor shall develop and implement a Quality Control Plan (QCP) to ensure quality and timely performance of Performance Work Statement (PWS) tasks.
- f. Maintenance/Repair. The preservation or restoration of a piece of equipment, a system, or a facility to such condition that it may be effectively utilized for its designated purposes. Maintenance/repair may be adjustment, overhaul, reprocessing, or replacement of constituent parts or materials that are missing or have deteriorated
by
action of the elements or usage, or replacement of the entire unit or system if beyond

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii
economical repair.

- g. Flight Line Clearances. The job site could be located within a restricted area. The contractor shall obtain Entry Authorization Letter (EAL) security clearances for personnel and equipment prior to commencing work. The Contractor shall ensure each employee obtains the proper pass and identification items applicable for the contract personnel and non-government owned vehicles.
- e. Regular Working Hours. The Government's regular (normal) working hours are from 0700 to 1600, Mondays through Fridays except (a) Federal Holidays and (b) other days specifically designated by the Contracting Officer.

A.4 GOVERNMENT FURNISHED PROPERTY AND SERVICES. The Government will not provide the Contractor option for use of certain Government owned facilities, equipment, materials, and utilities for use only in connection with this contract. The use of Government furnished property and services for other purposes is prohibited. All such facilities, equipment, and materials will be provided in "as is" condition.

Government Furnished Facilities. The Government will not provide office space and operational facilities to the Contractor. The Contractor shall secure and maintain the necessary office space and other facilities required for the performance of this contract at his/her own expense.

Government Furnished Equipment. The Contractor shall furnish all tools and equipment required for the performance of this contract. The Government will not provide tools or equipment to the Contractor.

- a. Government Furnished Material. The Government will not provide any materials to the Contractor.
- b. Security Police and Fire Protection. The government will furnish security police and fire protection at no cost to the contractor.
- c. Availability of Utilities. The Government will furnish the following utility service at existing outlets for use in those facilities provided by the Government, and as may be required for the work to be performed under the contract: electricity, fresh water, heating, cooling, and other utilities (except phones) to the contractor. Information concerning the location of existing outlets may be obtained from the KO. The Contractor shall provide and maintain, at his/her expense, the necessary service lines from existing Government outlets to the site of work.
- d. Utilities specified above will be furnished at no cost to the Contractor.
- e. Except for those items or services specifically stated in Section A.4 as government furnished, the contractor shall furnish everything needed to perform this contract according to all its terms. The contractor shall request and receive approval in writing from the KO or his/her designated representatives before bringing any

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

contractor owned equipment into the work area. All contractor owned equipment shall be conspicuously labeled as contractor owned.

- A.5 CONTRACTOR FURNISHED ITEMS. Except for items listed in clause A.4, the Contractor shall provide all facilities, equipment, materials, and services to perform the requirements of this contract. Contractor shall also provide UN Certified Hazardous waste containers for disposal of used LO Particulate filters.
- A.6 MANAGEMENT. The Contractor shall manage the total work effort associated with the maintenance, repair, and all other services required herein to assure fully adequate and timely completion of these services. Included in this function are a full range of management duties including, but not limited to, planning, scheduling, report preparation, establishing and maintaining records, and quality control. The Contractor shall provide an adequate staff of personnel with the necessary management expertise to assure the performance of the work in accordance with sound and efficient management practices.
- a. Work Control. The Contractor shall implement all necessary work control procedures to ensure timely accomplishment of work requirements, as well as to permit tracking of work in progress. The Contractor shall plan and schedule work to assure material, labor, and equipment are available to complete work requirements within the specified time limits and in conformance with the quality standards established herein. Verbal scheduling and status reports shall be provided when requested by the CO. The status of any item of work must be provided within 24 hours of the inquiry during regular working hours, and within 24 hours after regular working hours.
 - b. Work Schedule. The Contractor shall schedule and arrange work so as to cause the least interference with the normal occurrence of Government business and mission. In those cases where some interference may be essentially unavoidable, the Contractor shall make every effort to minimize the impact of the interference, inconvenience, equipment downtime, interrupted service, customer discomfort, etc. Contractor shall provide a minimum of 2 week notice of any filter change out and disposal of any Hazardous Waste materials.
 - c. Records and Reports. The Contractor shall maintain management, maintenance, and repair records and prepare management, maintenance, and repair reports. Monthly reports shall be submitted with the monthly invoice. A complete work (history) file for each system and equipment listed in Appendix A shall be maintained by the Contractor. Files shall contain a listing of all equipment in each building and room by nomenclature and manufacturer's model number, as well as all manufacturer's literature, brochures, and pamphlets; maintenance, operator's, and parts list manuals; warranty information; indefinite quantity delivery orders; and other information pertaining to system and equipment listed Appendix A. The entire file shall be turned over to the KO within five calendar days upon completion of the contract.
 - d. Building Managers. Within 10 calendar days following award of this contract, the KO will provide the Contractor with a list of building managers. The Contractor shall notify the building manager and COR at least two working days in advance of any

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

work to be performed in a building under their control that would tend to disrupt the conduct of normal Government business. Notification shall include the type of work to be done and the estimated completion date. The Contractor shall reschedule any work that the KO deems necessary to avoid unacceptable disruptions in the Government's business.

A.7 GENERAL REQUIREMENTS AND PROCEDURES.

- a. Standards. All workmanship shall meet the standards specified herein and shall be accomplished in conformance with approved and accepted standards of the industry; equipment manufacturers; all applicable activity, local, state, and federal standards; and all applicable building and safety codes, including the National Fire Protection Association, National Electric Code, etc.
 - (1) When the Contractor completes work on a system or piece of equipment, that system or piece of equipment shall be free of missing components or defects which would prevent it from functioning as originally intended and/or designed. Corrective or repair/replacement work shall be carried to completion including operational checks and cleanup of the job site. Except where otherwise noted, replacements shall match existing in dimensions, finish, color, and design.
 - (2) During and at completion of work, debris shall not be allowed to spread unnecessarily into adjacent areas nor accumulate in the work area itself. All such debris, excess material, and parts shall be cleaned up and removed at the completion of the job and/or at the end of each day work is in progress.
- b. As Built Drawings.
 - (1) Existing as-built drawings will be available to the Contractor.
- c. Interface with Other Contractors and Government Forces. Attention is invited to the fact that other Contractors and/or Government Forces are engaged in similar and supporting work, requiring close cooperation. The Contractor for this contract shall cooperate with all other Contractors and avoid conflicts with other Contractor's performance and work schedules. In the event of conflicts with other Contractors that cannot be satisfactorily resolved, the matter shall be referred to the KO for decision.
- d. Impairments (Emergency or Pre-Planned). The Contractor shall minimize the time which the existing system is out of service. Prior to any impairment of the existing system, the Contractor shall notify the KO.

A.8 STATION REGULATIONS. The Contractor and Contractor employees shall become acquainted with and obey all Government regulations as posted or as requested by the KO.

A.9 ENVIRONMENTAL COMPLIANCE. The Contractor shall comply with all applicable environmental compliance requirements. The Contractor shall comply with Federal, State,

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

and local laws and with the regulations and standards regarding environmental pollution. All environmental protection matters shall be coordinated with the KO. Contractor will work with KO to coordinate Hazardous Waste disposal with other agencies/departments and program managers. Inspection of any facilities operated by the Contractor may be accomplished by the KO, on a no-notice basis during regular working hours.

A.10 SAFETY REQUIREMENTS AND REPORTS.

- a. All work shall be conducted in a safe manner and shall comply with activity requirements. The Government will not provide safety equipment to the Contractor.
- b. Prior to commencing work, the Contractor shall meet with the KO and activity safety personnel to discuss and develop mutual understandings relative to administration of the safety program.
- c. The Contractor shall report to the KO in the manner and on the forms prescribed by the KO.
- d. Emergency medical care must be provided by the Contractor for Contractor employees who suffer on-the-job injury or disease at Contractor expense.

A.11 SECURITY REQUIREMENTS. The contractor shall comply with all activity security requirements.

A.12 PERMITS. The Contractor shall, without additional expense to the Government, obtain all appointments, licenses, and permits required for the prosecution of the work.

A.13 INSURANCE. Within fifteen (15) days after the award of this contract, the Contractor shall furnish the KO a certificate of insurance as evidence of the existence of the following insurance coverage in amounts not less than the amounts specified below in the Contract Clauses:

- a. The Contractor shall procure and maintain during the entire period of the performance under this contract the following minimum insurance coverage.
 - (1) Comprehensive General Liability: \$1,000,000 per occurrence.
 - (2) Automobile Liability: \$1,000,000 per person
 - (3) Workmen's Compensation: As required by Federal and State worker's compensation and occupational disease statutes.

Maintenance of LO/ Composite Facility
Joint Base Pearl Harbor-Hickam, Oahu, Hawaii

- (4) Employer's Liability coverage: \$1,000,000, except in states where worker's compensation may not be written by private carriers.
- (5) Other as required by State Law.

The Certificate of Insurance shall provide for thirty days written notice to the KO by the insurance company prior to cancellation or material change in policy coverage.

END OF PART II