

ADDENDUM NO. 2

**STATE OF HAWAII
DEPARTMENT OF DEFENSE
ENGINEERING OFFICE**

September 17, 2018

The Following are changes to the Scope of Work:

Title: Shall now read as PERFORMANCE WORK STATEMENT FOR OIL WATER SEPARATOR INSPECTION AND MAINTENANCE FOR COMBINED SUPPORT MAINTENANCE SHOP #1 AND BLDG. 30 KALAELOA

1. DESCRIPTION OF SERVICES

(Changed) ~~quarterly~~ to *annual* preventive maintenance

1.1

(Changed) ~~four (4) quarterly inspections~~ to *two (2) annual inspections and cleanings for Bldg. 117 Combined Maintenance Support Shop (CSMS#1), and one (1) annual inspection and cleaning at each OWS and OI for Bldg. 30*

1.2 OWS INSPECTION PROCEDURE

(Deleted) v. Examine operation of oil level sensor

(Deleted) vii. Test alarms for containment tank and OWS

(Deleted) viii. Test controls and alarm system including valve operation

1.4 DOCUMENTATION OF CLEANING AND SERVICE

(Deleted) A copy shall be sent to the R&M Engineer for the State of Hawaii Department of Defense

(Added) Contractor to fill out 'Pretreatment Device Maintenance Log' for each device, the Pretreatment Device Maintenance Log is located with the facility manager of each site

1.6 COORDINATION OF SCHEDULE

(Changed) There will be ~~four (4) quarterly~~ *two (2) annual* maintenance and service cleaning to be scheduled for October 2018, ~~January 2019, April 2019, and July~~ and *September 2019* for Bldg. 117 CSMS #1, and *one annual maintenance and service cleaning for Bldg. 30 to be scheduled for September 2019*

3.0 TIME

(Changed)

Proposed maintenance shall occur:

October 2018 and September 2019 for Bldg. 117 CSMS #1

September 2019 for Bldg. 30

The following are questions received and clarifications for Solicitation No. Q19000276, Oil Water Separator Maintenance Kalaeloa. The items in this addendum shall govern the work, taking precedence over previously issued specifications governing the items mentioned.

1. Will oil water separators at building 30 wash rack area be schedule only accordingly when they switch over the switch to divert water into oil holding area?

Please note that there will be an Amendment No. 2 to revise the inspections and servicing to two annual inspections for the Bldg. 117 CSMS#1, and one annual inspection for Bldg. 30. HIENG will defer the OWS maintenance and servicing of Bldg. 30 to September 2019

2. Can we remove inspecting controls of the oil water separator because we weren't able to view it during site visit ?

Please note that the Scope of Work has been amended with the following items deleted:

- 1.2.v Examine operation of oil level sensor
- 1.2.vii Test alarms for contaminant tank and OWS
- 1.2.viii Test controls and alarm system including valve operation

3. Will there be a max amount of liquid that state would like to not to exceed in this contract time period?

To reduce the amount of liquid, the OWS maintenance and servicing will be revised as followed:
Bldg 117 CSMS #1 to have two annual maintenance and service cleaning (October 2018 and September 2019)
Bldg 30 to have one annual maintenance and service cleaning (September 2019)

END OF ADDENDUM NO. 2