

NOTES:

- 1. CONCRETE SHALL HAVE A COMPRESSIVE STRENGTH OF 3000 PSI @ 28 DAYS, CONTAIN 4% MIN 6% MAX AIR ENTRAINMENT AND BE PLACED WITH A 3.50 4.50 SLUMP IN ACCORDANCE WITH ACI 301.
- 2. REINFORCING STEEL RODS SHALL CONFORM TO ASTM A615, GRADE 60.
- 3. ANCHOR BOLTS SHALL CONFORM TO ASTM A193, GRADE B8M, TYPE 316 STAINLESS STEEL.

Concrete Pad - Single Unit

LOCATION OF PADS

